BACTERIOLOGICAL SAMPLING \$100.00 48 HOUR RUSH ORDER PROCESSING FEE ADDITIONAL \$50.00

Start and Finish Dates: You will have 90 days from this date in	n order to complete this course	
List number of hours worked on assign	nment must match State Require	ment
Name	Signature_ on page 2. Digitally sign XXX	
Address		
City	State	Zip
Email	Fax () _	
Phone: Home ()	Work ()	
Operator ID #	Exp. Da	te
Please circle/check which certificat Water Treatment Water Distribut		
	ege TLC PO Box 3060, Chino V 46 Fax (928) 272-0747 <u>info@</u>	
If you've paid on the Internet, pleas	e write your Customer#	5 digit number
Please invoice me, my PO#		
Please pay with your credit card on		or Buy Now. Or call u

We will stop mailing the certificate of completion so we need either your fax number or email address. We will e-mail the certificate to you, if no e-mail address; we will fax it to you.

DISCLAIMER NOTICE

I understand that it is my responsibility to ensure that this CEU course is either approved or accepted in my State for CEU credit. I understand State laws and rules change on a frequent basis and I believe this course is currently accepted in my State for CEU or contact hour credit, if it is not, I will not hold Technical Learning College responsible. I also understand that this type of study program deals with dangerous conditions and that I will not hold Technical Learning College, Technical Learning Consultants, Inc. (TLC) liable for any errors or omissions or advice contained in this CEU education training course or for any violation or injury or neglect or damage caused by this CEU education training or course material suggestion or error. I will call or contact TLC if I need help or assistance and double-check to ensure my registration page and assignment has been received and graded.

State Approval Listing Link, check to see if your State accepts or has pre-approved this course. Not all States are listed. Not all courses are listed. If the course is not accepted for CEU credit, we will give you the course free if you ask your State to accept it for credit.

Professional Engineers; Most states will accept our courses for credit but we do not officially list the States or Agencies. Please check your State for approval.

State Approval Listing URL...

http://www.abctlc.com/downloads/PDF/CEU%20State%20Approvals.pdf

You can obtain a printed version of the course manual from TLC for an additional \$169.95 plus shipping charges.

AFFIDAVIT OF EXAM COMPLETION

I affirm that I personally completed the entire text of the course. I also affirm that I completed the exam without assistance from any outside source. I understand that it is my responsibility to file or maintain my certificate of completion as required by the state or by the designation organization.

Grading Information

In order to maintain the integrity of our courses we do not distribute test scores, percentages or questions missed. Our exams are based upon pass/fail criteria with the benchmark for successful completion set at 70%. Once you pass the exam, your record will reflect a successful completion and a certificate will be issued to you.

Rush Grading Service

If you need this assignment graded and the results mailed to you within a 48-hour period, prepare to pay an additional rush service handling fee of \$50.00. This fee may not cover postage costs. If you need this service, simply write RUSH on the top of your Registration Form. We will place you in the front of the grading and processing line.

For security purposes, please fax or e-mail a copy of your driver's license and always call us to confirm we've received your assignment and to confirm your identity.

CERTIFICATION OF COURSE PROCTOR

Technical Learning College requires that our students who takes a correspondence or home study program course must pass a proctored course reading, quiz and final examination. The proctor must complete and provide to the school a certification form approved by the commission for each examination administered by the proctor.

Instructions . When a student completes the course work, fill out the blanks in this section and provide the form to the proctor with the examination.
Name of Course:
Name of Licensee:
Instructions to Proctor. After an examination is administered, complete and return this certification and examination to the school in a sealed exam packet or in pdf format.
I certify that:
 I am a disinterested third party in the administration of this examination. I am not related by blood marriage or any other relationship to the licensee which would influence me from properly administering the examination. The licensee showed me positive photo identification prior to completing the examination. The enclosed examination was administered under my supervision on The licensee received no assistance and had no access to books, notes or reference material. I have not permitted the examination to be compromised, copied, or recorded in any way or by any method. Provide an estimate of the amount of time the student took to complete the assignment. Time to complete the entire course and final exam.
Notation of any problem or concerns:
Name and Telephone of Proctor (please print):
Signature of Proctor

BACTERIOLOGICAL SAMPLING ANSWER KEY

Name			
Phone			
Did you check with	your State agency to er	nsure this course is acce	pted for credit?
•		is accepted for credit. No n. Please fill this section	refunds.
Website Telephor	ne Call Email S	poke to	
Did you receive the	approval number, if ap	olicable?	
What is the course a	approval number, if app	licable?	
You can electronica	lly complete this assign	nment in Adobe Acrobat	DC.
Please Circle, Bold, U	Inderline or X, one answ	er per question. A felt tipp	ed pen works best.
1. ABCD	20. A B C D	39. A B C D	58. A B
2. ABCD	21. A B C D	40. A B C D	59. A B
3. A B C D	22. A B C D	41. A B C D	60. ABCD
4. ABCD	23. A B C D	42. A B C D	61. A B
5. ABCD	24. A B C D	43. A B C D	62. A B C D
6. ABCD	25. A B C D	44. A B C D	63. AB
7. ABCD	26. A B	45. A B C D	64. ABCD
8. A B C D	27. A B	46. A B	65. ABCD
9. ABCD	28. A B	47. A B	66. AB
10.A B C D	29. A B	48. A B	67. AB
11.A B C D	30. A B	49. A B C D	68. AB
12.A B C D	31. A B	50. A B C D	69. ABCD
13. A B C D	32. A B	51. A B C D	70. ABCD
14.A B C D	33. A B	52. A B C D	71. A B
15. A B C D	34. A B	53. A B C D	72. AB
16.ABCD	35. A B	54. A B C D	73. A B C D
17.A B C D	36. ABCD	55. A B C D	74. A B C D
18.A B C D	37. ABCD	56. A B	75. A B C D
19. A B C D	38. A B C D	57. A B	76. A B C D

Bac-T Sampling Assignment

57. AB 70. 75. TLC © 1/13/2020 www.abctlc.com

77. A B	83. A B C D	89. A B C D	95. ABCD
78. A B	84. A B C D	90. ABCD	96. ABCD
79. ABCD	85. ABCD	91. A B	97. ABCD
80. A B C D	86. ABCD	92. A B	98. A B
81. A B C D	87. ABCD	93. A B	99. A B
82. A B C D	88. ABCD	94. A B	100. ABCD

I understand that I am 100 percent responsible to ensure that TLC receives the Assignment and Registration Key and that it is accepted for credit by my State or Providence. I understand that TLC has a zero tolerance towards not following their rules, cheating or hostility towards staff or instructors. I need to complete the entire assignment for credit. There is no credit for partial assignment completion. My exam was proctored. I will contact TLC if I do not hear back from them within 2 days of assignment submission. I will forfeit my purchase costs and will not receive credit or a refund if I do not abide with TLC's rules. I will not hold TLC liable for any errors, injury, death or non-compliance with rules. I will abide with all federal and state rules and rules found on page 2.

Please Sign 1	that you understand	and will abide with	TLC's Rules.
---------------	---------------------	---------------------	--------------

	 	 	
Signature			

Please write down any questions you were not able to find the answers or that have errors.

Please e-mail or fax this survey along with your final exam

BACTERIOLOGICAL SAMPLING CEU COURSE CUSTOMER SERVICE RESPONSE CARD

NAME:							
E-MAIL						PHO	NE
PLEASE CO							THE NUMBER OF THE
Please rate	the diffi	culty of	f your c	ourse.			
Very Easy	0	1	2	3	4	5	Very Difficult
Please rate	the diffi	culty of	f the te	stina pr	ocess		
Very Easy	0	1	2	3	4	5	Very Difficult
Very Similar	0 i hear a	1 bout th	2 nis Cou	3 rse?	4	5	actual field or work. Very Different
Any other co	oncerns	or con	nments	·.			

When finished with your assignment.

Please scan the Registration Page, Answer Key and Driver's License and email it to info@TLCH2O.com.

If you are unable to scan, take a photo of these documents with your iPhone and send these to TLC, <u>info@TLCH2O.com</u>.

If you are unable to scan and email, please fax these to TLC,

(928) 468-0675
If you fax, call to confirm that we received your paperwork.

Rush Grading Service

If you need this assignment graded and the results mailed to you within a 48-hour period, prepare to pay an additional rush service handling fee of \$50.00.

This course contains general EPA's SDWA federal rule requirements. Please be aware that each state implements water / sampling procedures/ safety / environmental / SDWA regulations that may be more stringent than EPA's regulations. Check with your state environmental/health agency for more information. These rules change frequently and are often difficult to interpret and follow. Be careful to be in compliance with your regulatory agencies and do not follow this course for any compliance concerns.

Bacteriological Sampling CEU Training Course Assignment

The Bacteriological Sampling CEU course assignment is available in Word on the Internet for your convenience, please visit www.ABCTLC.com and download the assignment and e-mail it back to TLC.

You will have 90 days from receipt of this manual to complete it in order to receive your Professional Development Hours (PDHs) or Continuing Education Unit (CEU). A score of 70 % or better is necessary to pass this course. If you should need any assistance, please email or fax all concerns and the completed ANSWER KEY to info@tlch2o.com.

Select one answer per question. Please utilize the answer key. (s) on the answer will indicate either plural and singular tenses.

Hyperlink to the Glossary and Appendix

http://www.abctlc.com/downloads/PDF/WTGlossary.pdf

Three Types of Public Water Systems

- 1. Provides water to the same people at least six months a year, but not all year (for example: schools, factories, churches, office buildings that have their own water system)
- A. TNCWS C. NTNCWSs
- B. CWSs D. None of the above
- 2. Provides water where people do not remain for long periods of time (for example: gas stations, campgrounds)
- A. TNCWS C. NTNCWSs
- B. CWSs D. None of the above
- 3. Approximately 52,000 systems serving the majority of the U.S. population
- A. TNCWS C. NTNCWSs
- B. CWSs D. None of the above
- 4. Approximately 18,000 water systems
- A. TNCWS C. NTNCWSs
- B. CWSs D. None of the above

Water Quality Section

Surface (Raw) Water Introduction

- 5. Water passes runoffs and infiltrates the ground during precipitation; this runoff acquires a wide variety of ______that intensely alters its usefulness.
- A. Excess nutrients C. Dissolved or suspended impurities
- B. Biological actions D. None of the above
- 6. _____ enhancement and formation of policy measures (administrative and engineering) revolves around most effective types of treatment methods and/or chemicals.
- A. Universal solvent C. Surface water
- B. Water quality D. None of the above

Surface Water Properties	because will discolve most substances that
comes in contact.	because will dissolve most substances that
A. Universal solvent (C. Surface water
A. Universal solvent CB. Water quality	D. None of the above
, ,	
	water is turbidity. A measure of the cloudiness of water caused ne cloudy appearance of water caused by the presence of tiny
particles.	
A. Suspended particles (
B. Variations	D. None of the above
can be difficult to remove in the are generally required.	be existing in a water supply due to pollution, and these colloids he coagulation process. In this situation, higher coagulant dosages
A. Turbidity C. Tota	
B. Organic colloids D. None	e of the above
Turbidity MCL 10. An MCL for turbidity est disinfection. This characteristic A. Conductivity C. Tem B. Turbidity D. None	rablished by the EPA becauseinterferes with c of water changes the most rapidly after a heavy rainfall. perature e of the above
specifically total trihalomethal	es focuses on public health protection by limiting exposure to DBPs, nes and five haloacetic acids, which can form in water through
12is ur	earch and Regulations Summary nquestionably the most important step in the treatment of water for
drinking water supplies.	
A. DBP(s) (
B. Turbidity (particle)	D. None of the above
much greater than the risks from A. Disinfectants and DBPs (eath resulting from exposure to pathogens in drinking water is very om C. Natural organic matter precursors D. None of the above
Organisms Descriptors and 14. Chemo means A. Rock C. Chemical B. Organic D. None of the	
	C. Light D. None of the above

- 16. Anaerobic means...
- A. Without air C. Self (Inorganic carbon)
- B. With air D. None of the above
- 17. Photo means...
- A. Feed or nourish C. Light
- B. Other (Organic carbon) D. None of the above
- 18. Troph means...
- A. Feed or nourish C. Light
- B. Other (Organic carbon) D. None of the above
- 19. Litho means...
- A. Rock C. Light
- B. Organic D. None of the above
- 20. Organo means...
- A. Rock C. Light
- B. Organic D. None of the above
- 21. Auto means...
- A. Without airB. With airC. Self (Inorganic carbon)D. None of the above
- 22. Facultative means...
- A. Without airB. With air or without airC. Self (Inorganic carbon)D. None of the above
- 23. Aerobic means...
- A. Without airB. With airC. Self (Inorganic carbon)D. None of the above

Contaminants that may be present in sources of drinking water include:

- 24. Which of the following can be synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can come from gas stations, urban stormwater run-off, and septic systems?
- A. Organic chemical contaminants C. Inorganic contaminants
- B. Pesticides and herbicides D. Microbial contaminants
- 25. Which of the following, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife?
- A. Microbial contaminants C. Inorganic contaminants
- B. Pesticides and herbicides D. All of the above

Background

- 26. Coliform bacteria and chlorine residual are the only routine sampling and monitoring requirements for small ground water systems with chlorination. The coliform bacteriological sampling is governed by the Coliform Reduction amendment of the SDWA.
- A. True B. False

TCR

- 27. The TCR recommends most of the Public Water Systems (PWS) to monitor their distribution system for bacteria according to the written sample sitting plan for that system.
- A. True B. False
- 28. Coliform contamination may occur anywhere in the system, possibly due to problems such as; high-pressure conditions, line fluctuations, or wells, and therefore routine monitoring is required.

A. True B. False

Routine Sampling Requirements

- 29. If any TC+ sample is also E. coli-positive (EC+), then the EC+ sample result must be reported to the state by the end of the month that the PWS is notified.
- A. True B. False
- 30. If any routine sample is TC+, repeat samples are required. PWSs on quarterly or annual monitoring must take a minimum of one additional routine samples (known as additional routine monitoring) the quarter following a TC+ routine or repeat sample.
- A. True B. False
- 31. Reduced monitoring is general available for PWSs using only surface water and serving 1,000 or fewer persons that meet certain additional PWS criteria.
- A. True B. False
- 32. Total coliform samples must be collected by PWSs at sites that are representative of water quality throughout the distribution system according to a written sample siting plan subject to state review and revision.
- A. True B. False
- 33. For PWSs collecting more than one sample per month, collect total coliform samples at regular intervals throughout the month, except that ground water systems serving 4,900 or fewer people may collect all required samples on a single day if the samples are taken from different sites.
- A. True B. False
- 34. Reduced monitoring may be available for PWSs using only ground water and serving 1,000 or fewer persons that meet certain additional PWS criteria
- A. True B. False
- 35. Each total coliform-positive (TC+) routine sample must be tested for the presence of heterotrophic bacteria.
- A. True B. False

Dangerous Waterborne Microbes

- 36. Which of the following are not necessarily agents of disease may indicate the presence of disease-carrying organisms?
- A. Fecal coliform bacteria C. Shigella dysenteriae
- B. Cryptosporidium D. None of the above
- 37. Which of the following is a parasite that enters lakes and rivers through sewage and animal waste. It causes gastrointestinal illness (e.g. diarrhea, vomiting, and cramps)?
- A. Coliform Bacteria C. Protozoa
- B. Cryptosporidium D. None of the above

 38. Which of the following is a species of the rod-shaped bacterial genus Shi A. Fecal coliform bacteria C. Shigella dysenteriae B. Cryptosporidium D. None of the above 	gella?
 39. Which of the following can cause bacillary dysentery? A. Fecal coliform bacteria C. Shigella B. Cryptosporidium D. None of the above 	
 40. Which of the following are Gram-negative, non-spore-forming, facultation motile bacteria. A. Fecal coliform bacteria B. Cryptosporidium C. Shigellae D. None of the above 	vely anaerobic, non-
41. Which of the following are microscopic organisms that live in the intesting animals? They also live in the waste material, or feces, excreted from the intesting fecal coliform bacteria are present in high numbers in a water sample, it means received fecal matter from one source or another. A. Fecal coliform bacteria C. Shigella dysenteriae B. Cryptosporidium D. None of the above	intestinal tract. When
Bacteriological Monitoring Introduction 42. Which of the following are usually harmless, occur in high densities in the environment and are easily cultured in relatively simple bacteriological media. A. Indicator bacteria C. Viruses B. Amoebas D. None of the above	
 43. Indicators in common use today for routine monitoring of drinking water in coliforms, fecal coliforms, and? A. Cryptosporidium C. Escherichia coli (E. coli) B. Protozoa D. None of the above 	nclude total
 44. According to the text, the routine microbiological analysis of your water is A. Contamination C. Coliform bacteria B. Colloids D. None of the above 	for?
Methods 45. The MMO-MUG test, a product marketed as, is the most of sample results will be reported by the laboratories as simply coliforms present A. Colilert	
Microbial Regulations 46. One of the key regulations developed and implemented by the United S Protection Agency (USEPA) to counter pathogens in drinking water is Treatment Rule. A. True B. False	
47. Among Surface Water Treatment Rule provisions, the rule requires system, using surface water (or ground water under the direct influence of source, have sufficient treatment to reduce the source water concentrate coliform bacteria by at least 99.9% and 99.99%, respectively. A. True B. False	surface water) as its

- 48. The Surface Water Treatment Rule suggests treatment criteria to assure that these performance recommendations are met; they may include turbidity limits, disinfectant residual and disinfectant contact time conditions.
- A. True B. False

The three (3) types of samples are:

- 49. Samples collected following a coliform present routine sample. The number of repeat samples to be collected is based on the number of samples you normally collect.
- A. Repeat C. Routine
- B. Special D. None of the above
- 50. A PWS on state-approved annual monitoring has a Level 1 Assessment trigger in 2 consecutive years.
- A. Trigger: Level 1 Assessment
- C. All of the above
- B. Trigger: Level 2 Assessment
- D. None of the above
- 51. A PWS collecting fewer than 40 samples per month has 2 or more TC+ routine/ repeat samples in the same month.
- A. Trigger: Level 1 Assessment
- C. All of the above
- B. Trigger: Level 2 Assessment
- D. None of the above
- 52. A PWS fails to take every required repeat sample after any single TC+ sample
- A. Trigger: Level 1 Assessment
- C. All of the above
- B. Trigger: Level 2 Assessment
- D. None of the above
- 53. A PWS incurs an E. coli MCL violation.
- A. Trigger: Level 1 Assessment
- C. All of the above
- B. Trigger: Level 2 Assessment
- D. None of the above
- 54. A PWS collecting at least 40 samples per month has greater than 5.0 percent of the routine/repeat samples in the same month that are TC+.
- A. Trigger: Level 1 Assessment
- C. All of the above
- B. Trigger: Level 2 Assessment
- D. None of the above
- 55. A PWS has a second Level 1 Assessment within a rolling 12-month period.
- A. Trigger: Level 1 Assessment
- C. All of the above
- B. Trigger: Level 2 Assessment
- D. None of the above
- 56. Noncommunity and nontransient noncommunity public water systems will sample at the same frequency as a like sized community public water system if:
- 1. It has more than 1,000 daily population and has ground water as a source, or
- 2. It serves 25 or more daily population and utilizes surface water as a source or ground water under the direct influence of surface water as its source.
- A. True B. False

Maximum Contaminant Levels (MCLs)

- 57. State and federal laws establish standards for drinking water quality. Under normal circumstances when these standards are being met, the water is safe to drink with no threat to human health. These standards are known as maximum contaminant levels (MCL). When a particular contaminant exceeds its MCL a potential health threat may occur.
- A. True
- B. False

58. There are two types of MCL violations for coliform bacteria. The first is for total coliform; the second is an acute risk to health violation characterized by the confirmed presence of fecal coliform or E. coli.

A. True B. False

Positive or Coliform Present Results

59. If you are notified of a positive coliform test result you need to contact either the Drinking Water Program or your local county health department within 72 hours, or by the next business day after the MCL compliance violation

A. True B. False

60. With a positive total coliform sample and after you have contacted an agency for assistance. you will be instructed as to the proper repeat sampling procedures and possible corrective measures for solving the problem. It is very important to initiate the as the corrective measures will be based on those results.

A. Perform routine procedures C. Corrective measures

B. Repeat sampling immediately

D. None of the above

Heterotrophic Plate Count HPC

61. Heterotrophic Plate Count (HPC) --- formerly known as the Bac-T plate, is a procedure for estimating the number of live heterotrophic bacteria and measuring changes during water treatment and distribution in water or in swimming pools.

A. True

B. False

Heterotrophic Plate Count (Spread Plate Method)

62. Which of the following provides a technique to quantify the bacteriological activity of a sample?

A. Colonies C. Heterotrophic Plate Count

D. None of the above B. Agar

Total Coliforms

63. This MCL is based on the presence of total coliforms, and compliance is on a daily or weekly basis, depending on your water system type and state rule.

A. True B. False

64. For systems which collect fewer than _____ samples per month, no more than one sample per month may be positive. In other words, the second positive result (repeat or routine) in a month or quarter results in a MCL violation.

A. 40

C. 200

B. 100

D. None of the above

The following are acute violations:

65. Which determines a violation of nitrate?

A. Presence C. MCLG

D. None of the above B. MCL

Revised Total Coliform Rule (RTCR) Summary

66. EPA published the Revised Total Coliform Rule (RTCR) in the Federal Register (FR) on February 13, 2013 (78 FR 10269). It is the revision to the 1989 Total Coliform Rule (TCR).

A. True B. False

67. The RTCR upholds the purpose of the 1989 TCR to protect public health by ensuring the duplicity of the drinking water distribution system and monitoring for the absence of microbial contamination. A. True B. False
68. The RTCR establishes criteria for systems to qualify for and stay on for special increased monitoring, which could reduce water system problems for better system operation. A. True B. False
69. The water provider shall develop and follow a sample-siting plan that designates the PWS's collection schedule. This includes location of A. Routine and repeat water samples C. Microbial contamination B. Reduced monitoring D. Repeat water samples
70. The water provider shall collect on a regular basis (monthly, quarterly, annually). Have samples tested for the presence of total coliforms by a state certified laboratory. A. Routine water samples C. Microbial contamination B. Reduced monitoring D. Repeat water samples
71. The RTCR requires public water systems that are vulnerable to microbial contamination to identify and fix problems. A. True B. False
72. The water provider shall collect repeat samples (at least 3) for each TC+ positive routine sample. A. True B. False
73. For PWSs on quarterly or annual routine sampling, collect additional routine samples (at least 3) in the month after a A. CCR(s) C. Total coliform positive samples B. PN D. TC+ routine or repeat sample
74. PWSs incur violations if they do not comply with the requirements of the RTCR. The violation types are essentially the same as under the TCR with few changes. The biggest change is no acute or monthly MCL violation foronly. A. CCR(s) C. Total coliform positive samples B. PN D. TC+ routine or repeat sample
75. Community water systems (CWSs) must use specific language in their CCRs when they must conduct an assessment or if they incur A. CCR(s) C. An E. coli MCL violation B. PN D. TC+ routine or repeat sample
76. The water provider shall analyze all that are total coliform positive (TC+) for E. coli. A. Routine or repeat water samples C. Microbial contamination B. Reduced monitoring D. Repeat water samples
77. The RTCR requires public water systems (PWSs) to meet a legal limit for E. coli, as demonstrated by required monitoring. A. True B. False

78. The RTCR suggests the frequency and timing of required microbial testing based on, public water type and source water type.A. True B. False
Disinfection Key 79. The RTCR requires 99.99% or 4 log inactivation of A. Enteric viruses
80. The RTCR requires the chlorine residual leaving the plant must be = or mg/L and measurable throughout the system. A. > 0.2
81. The RTCR requires 99% or 2 log inactivation of A. Enteric viruses
82. The RTCR requires 99.9% or 3 log inactivation of A. Enteric viruses
Waterborne Pathogen Section - Introduction Pathogen Section 83. Most pathogens are generally associated with diseases that and affect people in a relatively short amount of time, generally a few days to two weeks. A. Cause intestinal illness
Protozoan Caused Diseases 84. Which of the following bugs is larger than bacteria and viruses but still microscopic; they invade and inhabit the gastrointestinal tract? A. Hepatitis A
85. Some of the parasites enter the environment in a dormant form, with a protective cell wall, called a? A. Lamblia C. Cyst B. Shell D. None of the above
Giardia lamblia 86. Which of the following bugs has been responsible for more community-wide outbreaks of disease in the U.S. than any other, and drug treatment are not 100% effective? A. Giardia lamblia C. Giardiasis B. Cryptosporidiosis D. None of the above
87. All of these diseases, with the exception of, have one symptom in common: diarrhea. They also have the same mode of transmission, fecal-oral, whether through person-to-person or animal-to-person contact. A. HIV infection C. Hepatitis A B. Giardiasis D. None of the above

Primary Waterborne Diseases Section
88. Legionnaire's disease, which causes a severe pneumonia, and the second,, which is a non-pneumonia illness; it's typically an influenza-like illness, and it's less severe.
A. Pontiac fever C. Typhoid fever
B. Yellow fever D. None of the above
89. Legionella, prevention. Legionella in water systems. Hot water in tanks should be maintained betweendegrees Centigrade. A. 81 to 100
90. Which of the following is typically associated with soil and water?
A. Hepatitis A virus C. Pseudomonas
B. Legionella D. None of the above
Waterborne Bacterial Diseases
91. Campylobacteriosis outbreaks have most often been associated with food, especially chicken and un-pasteurized milk, as well as un-chlorinated water. These organisms are also an important cause of "travelers' diarrhea." Medical treatment generally is not prescribed for campylobacteriosis because recovery is usually rapid. A. True B. False
92. Cholera, Legionellosis, salmonellosis, shigellosis, yersiniosis, are other bacterial diseases that can be transmitted through water. All bacteria in water are readily killed or inactivated with chlorine or other disinfectants. A. True B. False
93. Campylobacteriosis is the most common diarrheal illness caused by bacteria. Other symptoms include abdominal pain, malaise, fever, nausea and vomiting; and begin three to five days after exposure. The illness is frequently over within two to five days and usually lasts no more than 10 days. A. True B. False
Viruses Coronavirus 94. It looks like the COVID-19 coronavirus is not able to live in water. A. True B. False
Chain of Custody Procedures 95. If both parties involved in the transfer must sign, date and note the time on the chain of custody record, this is known as? A. TC Plan C. Samples transfer possession B. Sample siting plan D. None of the above
96. The recipient will then attach theshowing the transfer dates and times to the custody sheets. If the samples are split and sent to more than one laboratory, prepare a separate chain of custody record for each sample. A. Shipping invoices

(S) Means the answer can be plural or singular in nature

Water Laboratory Analysis Section

pH Testing Section

97. When an atom loses _____ and thus has more protons than electrons, the atom is a positively-charged ion or cation.

A. A proton C. An electron

B. Charge D. None of the above

98. Measurement of pH for aqueous solutions can be done with a glass electrode and a pH meter, or using indicators like strip test paper.

A. True B. False

99. In chemistry, pH is a measure of the acidity or basicity of an aqueous solution. Solutions with a pH greater than 7 are said to be acidic and solutions with a pH less than 7 are basic or alkaline.

A. True B. False

100. Pure water has a pH very close to?

A. 7 C. 7.7

B. 7.5 D. None of the above

When finished with your assignment.

Please scan the Registration Page, Answer Key and Driver's License and email it to info@TLCH2O.com.

If you are unable to scan, take a photo of these documents with your iPhone and send these to TLC, <u>info@TLCH2O.com</u>.

If you are unable to scan and email, please fax these to TLC,

(928) 468-0675
If you fax, call to confirm that we received your paperwork.