

Registration form

**Chlorination 303 CEU Training Course \$250.00
48 HOUR RUSH ORDER PROCESSING FEE ADDITIONAL \$50.00**

Start and Finish Dates: _____ *You will have 90 days from this date in order to complete this course*

List number of hours worked on assignment must match State Requirement. _____

Name _____ Signature _____
I have read and understood the disclaimer notice on page 2. Digitally sign XXX

Address: _____

City _____ State _____ Zip _____

Email _____ Fax (_____) _____

Phone:
Home (_____) _____ Work (_____) _____

Operator ID# _____ Exp Date _____

Please circle/check which certification you are applying the course CEU's.

Water Treatment _____ Distribution _____ Collection _____

Wastewater Treatment _____ Other _____

**Technical Learning College PO Box 3060, Chino Valley, AZ 86323
Toll Free (866) 557-1746 Fax (928) 272-0747 info@tlch2o.com**

If you've paid on the Internet, please write your Customer# _____
4 or 5 digit number

Please invoice me, my PO# _____

Please pay with your credit card on our website under Bookstore or Buy Now. Or call us and provide your credit card information.

We will stop mailing the certificate of completion we need your e-mail address. We will e-mail the certificate to you, if no e-mail address; we will mail it to you.

DISCLAIMER NOTICE

I understand that it is my responsibility to ensure that this CEU course is either approved or accepted in my State for CEU credit. I understand State laws and rules change on a frequent basis and I believe this course is currently accepted in my State for CEU or contact hour credit, if it is not, I will not hold Technical Learning College responsible. I fully understand that this type of study program deals with dangerous, changing conditions and various laws and that I will not hold Technical Learning College, Technical Learning Consultants, Inc. (TLC) liable in any fashion for any errors, omissions, advice, suggestions or neglect contained in this CEU education training course or for any violation or injury, death, neglect, damage or loss of your license or certification caused in any fashion by this CEU education training or course material suggestion or error or my lack of submitting paperwork. It is my responsibility to call or contact TLC if I need help or assistance and double-check to ensure my registration page and assignment has been received and graded. It is my responsibility to ensure all information is correct and to abide with all rules and regulations.

State Approval Listing Link, check to see if your State accepts or has pre-approved this course. Not all States are listed. Not all courses are listed. If the course is not accepted for CEU credit, we will give you the course free if you ask your State to accept it for credit.

Professional Engineers; Most states will accept our courses for credit but we do not officially list the States or Agencies. Please check your State for approval.

State Approval Listing URL...

<http://www.abctlc.com/downloads/PDF/CEU%20State%20Approvals.pdf>

You can obtain a printed version of the course from TLC for an additional \$169.95 plus shipping charges.

AFFIDAVIT OF EXAM COMPLETION

I affirm that I personally completed the entire text of the course. I also affirm that I completed the exam without assistance from any outside source. I understand that it is my responsibility to file or maintain my certificate of completion as required by the state or by the designation organization.

Grading Information

In order to maintain the integrity of our courses we do not distribute test scores, percentages or questions missed. Our exams are based upon pass/fail criteria with the benchmark for successful completion set at 70%. Once you pass the exam, your record will reflect a successful completion and a certificate will be issued to you.

All downloads are tracked and monitored for security purposes.

Chlorination 303 CEU Course Answer Key

Name _____ Telephone # _____

Method of Course acceptance confirmation. Please fill this section

It is your sole responsibility to ensure this course is accepted for credit in your State. No refunds. Did you check with your State agency to ensure this course is accepted for credit?

Website ___ Telephone Call ___ Email ___ Spoke to _____

Did you receive the approval number, if applicable? _____

What is the course approval number, if applicable? _____

Please circle, underline, bold or X only one correct answer

Please Circle, Bold, Underline or X, one answer per question. A **felt tipped pen** works best.

- | | | | |
|-------------|-------------|-------------|-------------|
| 1. A B C D | 16. A B C D | 31. A B C D | 46. A B |
| 2. A B C D | 17. A B C D | 32. A B C D | 47. A B |
| 3. A B C D | 18. A B C D | 33. A B C D | 48. A B C D |
| 4. A B C D | 19. A B C D | 34. A B C D | 49. A B C D |
| 5. A B C D | 20. A B C D | 35. A B | 50. A B C D |
| 6. A B C D | 21. A B C D | 36. A B | 51. A B C D |
| 7. A B C D | 22. A B C D | 37. A B C D | 52. A B C D |
| 8. A B C D | 23. A B C D | 38. A B C D | 53. A B C D |
| 9. A B C D | 24. A B C D | 39. A B C D | 54. A B C D |
| 10. A B | 25. A B C D | 40. A B C D | 55. A B |
| 11. A B C D | 26. A B C D | 41. A B | 56. A B |
| 12. A B C D | 27. A B | 42. A B | 57. A B |
| 13. A B C D | 28. A B C D | 43. A B | 58. A B |
| 14. A B C D | 29. A B C D | 44. A B | 59. A B |
| 15. A B C D | 30. A B C D | 45. A B | 60. A B |

61. A B
62. A B
63. A B
64. A B C D
65. A B C D
66. A B
67. A B
68. A B C D
69. A B C D
70. A B C D
71. A B C D
72. A B C D
73. A B C D
74. A B C D
75. A B C D
76. A B C D
77. A B C D
78. A B C D
79. A B C D
80. A B C D
81. A B C D
82. A B
83. A B C D
84. A B C D
85. A B C D
86. A B C D
87. A B C D
88. A B C D
89. A B C D
90. A B
91. A B
92. A B
93. A B

94. A B C D
95. A B C D
96. A B C D
97. A B C D
98. A B C D
99. A B C D
100. A B C D
101. A B C D
102. A B C D
103. A B C D
104. A B C D
105. A B C D
106. A B C D
107. A B C D
108. A B C D
109. A B C D
110. A B C D
111. A B C D
112. A B C D
113. A B C D
114. A B C D
115. A B C D
116. A B C D
117. A B C D
118. A B C D
119. A B C D
120. A B C D
121. A B C D
122. A B C D
123. A B C D
124. A B C D
125. A B C D
126. A B C D

127. A B C D
128. A B C D
129. A B C D
130. A B C D
131. A B C D
132. A B C D
133. A B C D
134. A B C D
135. A B C D
136. A B C D
137. A B C D
138. A B C D
139. A B C D
140. A B C D
141. A B C D
142. A B C D
143. A B C D
144. A B C D
145. A B C D
146. A B C D
147. A B C D
148. A B
149. A B
150. A B
151. A B
152. A B C D
153. A B C D
154. A B C D
155. A B C D
156. A B C D
157. A B C D
158. A B C D
159. A B C D

160. A B C D
161. A B C D
162. A B C D
163. A B C D
164. A B C D
165. A B C D
166. A B C D
167. A B C D
168. A B
169. A B
170. A B
171. A B
172. A B
173. A B
174. A B
175. A B C D
176. A B C D
177. A B C D
178. A B C D
179. A B C D
180. A B
181. A B
182. A B C D
183. A B C D
184. A B C D
185. A B C D
186. A B C D
187. A B C D
188. A B C D
189. A B C D
190. A B C D
191. A B C D
192. A B C D

193. A B
194. A B
195. A B
196. A B C D
197. A B C D
198. A B C D
199. A B C D
200. A B C D
201. A B C D
202. A B C D
203. A B C D
204. A B
205. A B
206. A B
207. A B
208. A B
209. A B C D
210. A B C D
211. A B C D
212. A B C D
213. A B C D
214. A B C D
215. A B C D
216. A B C D
217. A B
218. A B
219. A B C D
220. A B C D
221. A B C D
222. A B C D
223. A B C D
224. A B C D
225. A B C D

226. A B C D
227. A B C D
228. A B C D
229. A B C D
230. A B
231. A B
232. A B C D
233. A B C D
234. A B
235. A B
236. A B C D
237. A B
238. A B
239. A B
240. A B C D
241. A B C D
242. A B C D
243. A B C D
244. A B C D
245. A B C D
246. A B C D
247. A B C D
248. A B C D
249. A B C D
250. A B C D
251. A B C D
252. A B C D
253. A B C D
254. A B C D
255. A B C D
256. A B C D
257. A B C D
258. A B C D

259. A B C D
260. A B C D
261. A B
262. A B
263. A B
264. A B
265. A B C D
266. A B C D
267. A B C D
268. A B C D
269. A B
270. A B
271. A B
272. A B
273. A B
274. A B
275. A B
276. A B C D
277. A B C D
278. A B C D
279. A B C D
280. A B C D
281. A B
282. A B
283. A B
284. A B
285. A B
286. A B
287. A B C D
288. A B C D
289. A B C D
290. A B C D
291. A B C D

292. A B C D
293. A B
294. A B
295. A B C D
296. A B C D
297. A B C D
298. A B
299. A B C D
300. A B
301. A B C D
302. A B C D
303. A B C D
304. A B C D
305. A B C D
306. A B C D
307. A B C D
308. A B C D
309. A B C D
310. A B C D
311. A B C D
312. A B C D
313. A B C D
314. A B C D
315. A B C D
316. A B
317. A B
318. A B
319. A B C D
320. A B C D
321. A B C D
322. A B C D
323. A B C D
324. A B C D

- | | | | |
|--------------|--------------|--------------|--------------|
| 325. A B C D | 344. A B C D | 363. A B C D | 382. A B C D |
| 326. A B C D | 345. A B C D | 364. A B C D | 383. A B C D |
| 327. A B C D | 346. A B C D | 365. A B C D | 384. A B C D |
| 328. A B C D | 347. A B C D | 366. A B C D | 385. A B C D |
| 329. A B C D | 348. A B C D | 367. A B C D | 386. A B C D |
| 330. A B C D | 349. A B C D | 368. A B C D | 387. A B C D |
| 331. A B C D | 350. A B C D | 369. A B C D | 388. A B |
| 332. A B C D | 351. A B C D | 370. A B C D | 389. A B |
| 333. A B C D | 352. A B C D | 371. A B C D | 390. A B |
| 334. A B C D | 353. A B C D | 372. A B C D | 391. A B C D |
| 335. A B C D | 354. A B C D | 373. A B C D | 392. A B C D |
| 336. A B C D | 355. A B | 374. A B C D | 393. A B C D |
| 337. A B C D | 356. A B | 375. A B C D | 394. A B |
| 338. A B C D | 357. A B | 376. A B C D | 395. A B |
| 339. A B C D | 358. A B | 377. A B C D | 396. A B C D |
| 340. A B C D | 359. A B | 378. A B C D | 397. A B |
| 341. A B C D | 360. A B C D | 379. A B C D | 398. A B C D |
| 342. A B C D | 361. A B C D | 380. A B C D | 399. A B C D |
| 343. A B C D | 362. A B C D | 381. A B C D | 400. A B C D |

I understand that I am 100 percent responsible to ensure that TLC receives the Assignment and Registration Key. I will not hold TLC liable for any errors or damages and will abide with rules on page 2. I understand that TLC has a zero tolerance towards not following their rules, cheating or hostility towards staff or instructors. I need to complete the entire assignment for credit. There is no credit for partial assignment completion. My exam was proctored.

I will contact TLC if I do not hear back from them within 2 days of assignment submission. I will forfeit my purchase costs and will not receive credit or a refund if I do not abide with TLC's rules.

Please Sign that you understand and will abide with TLC's Rules.

Signature

Please write down any questions you were not able to find the answers or that have errors

Please e-mail or fax this survey along with your final exam

**CHLORINATION 303 CEU TRAINING COURSE
CUSTOMER SERVICE RESPONSE CARD**

NAME: _____

E-MAIL _____ PHONE _____

PLEASE COMPLETE THIS FORM BY CIRCLING THE NUMBER OF THE APPROPRIATE ANSWER IN THE AREA BELOW.

Please rate the difficulty of your course.

Very Easy 0 1 2 3 4 5 Very Difficult

Please rate the difficulty of the testing process.

Very Easy 0 1 2 3 4 5 Very Difficult

Please rate the subject matter on the exam to your actual field or work.

Very Similar 0 1 2 3 4 5 Very Different

How did you hear about this Course? _____

What would you do to improve the Course?

Any other concerns or comments.

When Finished with Your Assignment

REQUIRED DOCUMENTS

Please scan the **Registration Page, Answer Key, Survey and Driver's License** and email it to info@TLCH2O.com.

IPhone Scanning Instructions

If you are unable to scan, take a photo of these documents with your **iPhone** and send these photos to TLC, info@TLCH2O.com.

FAX

If you are unable to scan and email, please fax these to TLC, if you fax, call to confirm that we received your paperwork. **(928) 468-0675**

This course contains general EPA's SDWA federal rule requirements. Please be aware that each state implements water / sampling procedures/safety/ environmental / building regulations that may be more stringent than EPA's regulations. Check with your state environmental/health agency for more information. These rules change frequently and are often difficult to interpret and follow. Be careful to not be in non-compliance and do not follow this course for proper compliance.

Chlorination 303 CEU Course Assignment

The Chlorination 303 CEU Assignment is available in Word on the Internet for your Convenience, please visit www.ABCTLIC.com and download the assignment and e-mail it back to TLC.

You will have 90 days from the start of this course to complete in order to receive your Professional Development Hours (PDHs) or Continuing Education Unit (CEU). A score of 70 % is necessary to pass this course. If you should need any assistance, please email all concerns and the completed manual to info@tlch2o.com.

We would prefer that you utilize the enclosed answer sheet in the front, but if you are unable to do so, type out your own answer key. Please include your name and address on your manual and make copy for yourself.

Multiple Choice, please select only one answer per question. There are no intentional trick questions.

Waterborne Pathogens Section

Protozoan Caused Diseases

1. Some of the parasites enter the environment in a dormant form, with a protective cell wall, called a?
A. Lamblia C. Cyst
B. Shell D. None of the above
2. Which of the following bugs is larger than bacteria and viruses but still microscopic; they invade and inhabit the gastrointestinal tract?
A. Hepatitis A C. Protozoan pathogens
B. E.coli D. None of the above

Giardia lamblia

3. All of these diseases, with the exception of _____, have one symptom in common: diarrhea. They also have the same mode of transmission, fecal-oral, whether through person-to-person or animal-to-person contact.
A. HIV infection C. Hepatitis A
B. Giardiasis D. None of the above
4. Which of the following bugs has been responsible for more community-wide outbreaks of disease in the U.S. than any other, and drug treatment are not 100% effective?
A. Giardia lamblia C. Giardiasis
B. Cryptosporidiosis D. None of the above

Primary Waterborne Diseases Section

5. Humans are the reservoir for the Salmonella typhi pathogen, which causes diarrheal illness, and also known as?
A. Campylobacter C. Typhoid fever
B. Shigella dysenteriae D. None of the above
6. Legionnaire's disease, which causes a severe pneumonia, and the second, _____, which is a non-pneumonia illness; it's typically an influenza-like illness, and it's less severe.
A. Pontiac fever C. Typhoid fever
B. Yellow fever D. None of the above

7. Legionella, prevention. Legionella in water systems. Hot water in tanks should be maintained between _____ degrees Centigrade.

- A. 81 to 100
- B. 110 to 210
- C. 71 and 77
- D. None of the above

8. Which of the following is typically associated with soil and water?

- A. Hepatitis A virus
- B. Legionella
- C. Pseudomonas
- D. None of the above

9. Humans are the reservoir for the Norovirus. Prevention strategies for this pathogen include?

- A. Internal protection
- B. Source protection
- C. Containment protection
- D. None of the above

10. Cryptosporidium, prevention. Prevention strategies for this pathogen include source protection. A CT value of 50 is required when dealing with fecally accidents. CT equals a concentration, in parts per million, while time equals a contact time in minutes.

- A. True
- B. False

11. Giardia prevention strategies for this pathogen include _____; filtration, coagulation, and halogenation of drinking water.

- A. Internal protection
- B. Source protection
- C. Containment protection
- D. None of the above

12. Schistosomatidae, the basics. It is a parasite. It is acquired through dermal contact, cercarial dermatitis. It is commonly known as?

- A. Swimmer's itch
- B. Beaver fever
- C. Hemorrhagic colitis
- D. None of the above

Dangerous Waterborne Microbes

13. Which of the following is a parasite that enters lakes and rivers through sewage and animal waste. It causes gastrointestinal illness (e.g. diarrhea, vomiting, and cramps)?

- A. Coliform Bacteria
- B. Cryptosporidium
- C. Protozoa
- D. None of the above

14. Which of the following is a species of the rod-shaped bacterial genus Shigella?

- A. Fecal coliform bacteria
- B. Cryptosporidium
- C. Shigella dysenteriae
- D. None of the above

15. Which of the following is a parasite that enters lakes and rivers through sewage and animal waste. It causes cryptosporidiosis, a mild gastrointestinal disease. The disease can be severe or fatal for people with severely weakened immune systems.

- A. Coliform Bacteria
- B. Cryptosporidium
- C. Giardia lamblia
- D. None of the above

16. Which of the following are not necessarily agents of disease may indicate the presence of disease-carrying organisms?

- A. Fecal coliform bacteria
- B. Cryptosporidium
- C. Shigella dysenteriae
- D. None of the above

(S) Means the answer can be plural or singular in nature

17. Which of the following can cause bacillary dysentery?

- A. Fecal coliform bacteria
- B. Cryptosporidium
- C. Shigella
- D. None of the above

18. Which of the following are Gram-negative, non-spore-forming, facultatively anaerobic, non-motile bacteria.

- A. Fecal coliform bacteria
- B. Cryptosporidium
- C. Shigellae
- D. None of the above

19. Which of the following are microscopic organisms that live in the intestines of warm-blooded animals? They also live in the waste material, or feces, excreted from the intestinal tract. When fecal coliform bacteria are present in high numbers in a water sample, it means that the water has received fecal matter from one source or another.

- A. Fecal coliform bacteria
- B. Cryptosporidium
- C. Shigella dysenteriae
- D. None of the above

20. Which of the following are common in the environment and are generally not harmful? However, the presence of these bacteria in drinking water are usually a result of a problem with the treatment system or the pipes which distribute water, and indicates that the water may be contaminated with germs that can cause disease.

- A. Coliform Bacteria
- B. Cryptosporidium
- C. Giardia lamblia
- D. None of the above

21. Which of the following are bacteria whose presence indicates that the water may be contaminated with human or animal wastes? Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms.

- A. Fecal Coliform and E. coli
- B. Cryptosporidium
- C. Shigella dysenteriae
- D. None of the above

Bacteriological Monitoring Introduction

22. Which of the following are usually harmless, occur in high densities in their natural environment and are easily cultured in relatively simple bacteriological media?

- A. Indicator bacteria
- B. Amoebas
- C. Viruses
- D. None of the above

23. Indicators in common use today for routine monitoring of drinking water include total coliforms, fecal coliforms, and?

- A. Cryptosporidium
- B. Protozoa
- C. Escherichia coli (E. coli)
- D. None of the above

24. According to the text, the routine microbiological analysis of your water is for?

- A. Contamination
- B. Colloids
- C. Coliform bacteria
- D. None of the above

Bacteria Sampling

25. Water samples for _____ must always be collected in a sterile container.

- A. Amoebas
- B. Bacteria tests
- C. Viruses
- D. None of the above

(S) Means the answer can be plural or singular in nature

Methods

26. The MMO-MUG test, a product marketed as _____, is the most common. The sample results will be reported by the laboratories as simply coliforms present or absent.
- A. Colilert
 - B. Coliform
 - C. Total coliform analysis
 - D. None of the above

Basic Types of Water Samples

27. It is important to properly identify the type of sample you are collecting.
- A. True
 - B. False

The three (3) types of samples are:

28. A PWS on state-approved annual monitoring has a Level 1 Assessment trigger in 2 consecutive years.
- A. Trigger: Level 1 Assessment
 - B. Trigger: Level 2 Assessment
 - C. All of the above
 - D. None of the above
29. A PWS collecting fewer than 40 samples per month has 2 or more TC+ routine/ repeat samples in the same month.
- A. Trigger: Level 1 Assessment
 - B. Trigger: Level 2 Assessment
 - C. All of the above
 - D. None of the above
30. Samples collected following a coliform present routine sample. The number of repeat samples to be collected is based on the number of _____ samples you normally collect.
- A. Repeat
 - B. Special
 - C. Routine
 - D. None of the above
31. A PWS fails to take every required repeat sample after any single TC+ sample
- A. Trigger: Level 1 Assessment
 - B. Trigger: Level 2 Assessment
 - C. All of the above
 - D. None of the above
32. A PWS incurs an E. coli MCL violation.
- A. Trigger: Level 1 Assessment
 - B. Trigger: Level 2 Assessment
 - C. All of the above
 - D. None of the above
33. A PWS collecting at least 40 samples per month has greater than 5.0 percent of the routine/repeat samples in the same month that are TC+.
- A. Trigger: Level 1 Assessment
 - B. Trigger: Level 2 Assessment
 - C. All of the above
 - D. None of the above
34. A PWS has a second Level 1 Assessment within a rolling 12-month period.
- A. Trigger: Level 1 Assessment
 - B. Trigger: Level 2 Assessment
 - C. All of the above
 - D. None of the above
35. Noncommunity and nontransient noncommunity public water systems will sample at the same frequency as a like sized community public water system if:
- 1. It has more than 1,000 daily population and has ground water as a source, or
 - 2. It serves 25 or more daily population and utilizes surface water as a source or ground water under the direct influence of surface water as its source.
- A. True
 - B. False
36. Noncommunity and nontransient, noncommunity water systems with less than 10,000 daily population and groundwater as a source will sample on an annual basis.

- A. True B. False

Positive or Coliform Present Results

37. With a positive total coliform sample, and after you have contacted an agency for assistance, you will be instructed as to the proper repeat sampling procedures and possible corrective measures for solving the problem. It is very important to initiate the _____ as the corrective measures will be based on those results.

- A. Perform routine procedures C. Corrective measures
B. Repeat sampling immediately D. None of the above

Heterotrophic Plate Count (Spread Plate Method)

38. Which of the following provides a technique to quantify the bacteriological activity of a sample?

- A. Colonies C. Heterotrophic Plate Count
B. Agar D. None of the above

Total Coliforms

39. For systems which collect fewer than _____ samples per month, no more than one sample per month may be positive. In other words, the second positive result (repeat or routine) in a month or quarter results in a MCL violation.

- A. 40 C. 200
B. 100 D. None of the above

The following are acute violations:

40. Which determines a violation of nitrate?

- A. Presence C. MCLG
B. MCL D. None of the above

Revised Total Coliform Rule (RTCR) Summary

41. EPA published the Revised Total Coliform Rule (RTCR) in the Federal Register (FR) on February 13, 2013 (78 FR 10269). It is the revision to the 1989 Total Coliform Rule (TCR).

- A. True B. False

42. The RTCR upholds the purpose of the 1989 TCR to protect public health by ensuring the duplicity of the drinking water distribution system and monitoring for the absence of microbial contamination.

- A. True B. False

43. The RTCR establishes criteria for systems to qualify for and stay on for special increased monitoring, which could reduce water system problems for better system operation.

- A. True B. False

44. The RTCR requires public water systems that are vulnerable to microbial contamination to identify and fix problems.

- A. True B. False

45. The water provider shall collect repeat samples (at least 3) for each TC+ positive routine sample.

- A. True B. False

46. The RTCR requires public water systems (PWSs) to meet a legal limit for E. coli, as demonstrated by required monitoring.
A. True B. False
47. The RTCR suggests the frequency and timing of required microbial testing based on, public water type and source water type.
A. True B. False
48. The water provider shall develop and follow a sample-siting plan that designates the PWS's collection schedule. This includes location of _____.
A. Routine and repeat water samples C. Microbial contamination
B. Reduced monitoring D. Repeat water samples
49. The water provider shall collect _____ on a regular basis (monthly, quarterly, annually). Have samples tested for the presence of total coliforms by a state certified laboratory.
A. Routine water samples C. Microbial contamination
B. Reduced monitoring D. Repeat water samples
50. PN is required for violations incurred. Within required timeframes, the PWS must use the required health effects language and notify the public if they did not comply with certain requirements of the RTCR. The type of _____ depends on the severity of the violation.
A. CCR(s) C. MCL violation
B. PN D. TC+ routine or repeat sample
51. For PWSs on quarterly or annual routine sampling, collect additional routine samples (at least 3) in the month after a _____.
A. CCR(s) C. Total coliform positive samples
B. PN D. TC+ routine or repeat sample
52. PWSs incur violations if they do not comply with the requirements of the RTCR. The violation types are essentially the same as under the TCR with few changes. The biggest change is no acute or monthly MCL violation for _____ only.
A. CCR(s) C. Total coliform positive samples
B. PN D. TC+ routine or repeat sample
53. Community water systems (CWSs) must use specific language in their CCRs when they must conduct an assessment or if they incur _____.
A. CCR(s) C. An E. coli MCL violation
B. PN D. TC+ routine or repeat sample
54. The water provider shall analyze all _____ that are total coliform positive (TC+) for E. coli.
A. Routine or repeat water samples C. Microbial contamination
B. Reduced monitoring D. Repeat water samples

Summary

Detailed Disinfection Supplement Section

Factors in Chlorine Disinfection: Concentration and Contact Time

55. CXT values [final free chlorine concentration (mg/L) multiplied by minimum contact time (minutes)], offer water operators guidance in computing an effective combination of chlorine concentration and chlorine contact time required to achieve disinfection of water at a given temperature.

A. True B. False

56. The CXT formula demonstrates that if an operator chooses to decrease the chlorine concentration, the required contact time must be lengthened.

A. True B. False

57. As higher strength chlorine solutions are used, contact times may be reduced.

A. True B. False

Understanding Cryptosporidiosis

58. Cryptosporidium is an emerging parasitic protozoan pathogen because its transmission has increased dramatically over the past two decades.

A. True B. False

Disinfection Rule Section

Safe Drinking Water Act (SDWA) Review

59. The states are expected to administer and enforce these regulations for public water systems (systems that either have 25 or more service connections or regularly serve an average of 50 or more people daily for at least 60 days each year).

A. True B. False

60. Public water systems must provide water treatment, ensure proper drinking water quality through monitoring, and provide public notification of contamination problems.

A. True B. False

Relating to prevention of waterborne disease, the SDWA required EPA to:

61. Set numerical standards, referred to as Maximum Contaminant Levels (MCLs — the highest allowable contaminant concentrations in drinking water) or treatment technique requirements for contaminants in public water supplies;

A. True B. False

62. Issue regulations requiring monitoring of all regulated and certain unregulated contaminants, depending on the number of people served by the system, the source of the water supply, and the contaminants likely to be found;

A. True B. False

63. Set criteria under which systems are obligated to filter water from surface water sources; it must also develop procedures for states to determine which systems have to filter.

A. True B. False

Chlorine DDBP

64. These term means that chlorine is present as Cl , HOCl , and OCl^- is called _____, and that which is bound but still effective is _____.

- A. Free available chlorine and Total
- B. Free and Residual
- C. Free available chlorine and Combined Chlorine
- D. None of the above

65. Chloramines are formed by reactions with?

- A. Acid and Cl_2
- B. Ammonia and Cl_2
- C. Folic Acid and Cl_2
- D. None of the above

EPA's Drinking Water Regulations for Disinfectants

66. Chlorine is the most widely used water disinfectant due to its effectiveness and cost.

- A. True
- B. False

67. Using chlorine as a drinking water disinfectant has prevented millions of water borne diseases, such as typhoid, cholera, dysentery, and diarrhea. Most states require community water systems to use chlorination.

- A. True
- B. False

68. All disinfectants form DBPs in one of two reactions: Chlorine and chlorine-based compounds (halogens) react with organics in water causing the _____ to substitute other atoms resulting in halogenated by-products.

- A. Chlorine atom
- B. Hydrogen atom
- C. Carbon atom
- D. None of the above

69. Oxidation reactions are where chlorine _____ compounds present in water.

- A. Reduces
- B. Forms
- C. Oxidizes
- D. None of the above

70. _____ are also formed when multiple disinfectants are used.

- A. Secondary by-products
- B. Primary by-products
- C. Chlorine and chlorine-based compounds (halogens)
- D. None of the above

71. Which of the following rules requires systems using public water supplies from either surface water or groundwater under the direct influence of surface water to disinfect?

- A. TTHM and HAA5 Rule
- B. DBP MCLs Rule
- C. Surface Water Treatment Rule (SWTR)
- D. None of the above

72. The maximum contaminant level for the SWTR disinfection set by EPA. At this time, an MCL is set for only _____, and proposed for additional disinfection byproducts.

- A. TTHM and HAA5 Rule
- B. Total Trihalomethanes
- C. A community water system (CWS)
- D. None of the above

73. Which of the following rules apply to all community and non-community water systems using a disinfectant such as chlorine, chloramines, ozone and chlorine dioxide?

- A. TTHM and HAA5 Rule
- B. Disinfectants and Disinfection Byproducts (DBP)
- C. A community water system (CWS)
- D. None of the above

74. The Long Term 2 Enhanced Surface Water Treatment Rule (LT2) rule applies to all water systems using _____ under the influence of a surface water, as well as groundwater/surface water blends.

- A. Surface water, groundwater
- B. Disinfection byproducts (DBPs) Rule
- C. DBP MCLs Rule
- D. None of the above

75. Which of the following rules began in 2006 with the characterization of raw water Cryptosporidium and E. coli levels?

- A. DBPs requirements
- B. The LT2 requirements
- C. Stage 1 Disinfectant and Disinfection Byproduct Rule
- D. None of the above

76. Which of the following rules applies to all public water systems using groundwater?

- A. Groundwater Rule (GWR)
- B. SDWA in 1996
- C. Long Term 2 Enhanced Surface Rule (LT2)
- D. None of the above

77. Which of the following rules require EPA to develop rules to balance the risks between microbial pathogens and disinfection byproducts?

- A. Amendments to the SDWA in 1996
- B. SDWA in 1996
- C. Stage 1 Disinfectant and Disinfection Byproduct Rule
- D. None of the above

Public Health Concerns

78. Which of the following rules along with the Disinfection Byproducts Rule applies to all community and nontransient non-community water systems that treat their water with a chemical disinfectant?

- A. Groundwater Rule (GWR)
- B. The Stage 1 Disinfectants
- C. Long Term 2 Enhanced Surface Water Treatment Rule
- D. None of the above

79. Which of the following rules and Disinfection Byproduct Rule updates and supersedes the 1979 regulations for total trihalomethanes?

- A. DBPs
- B. The LT2 requirements
- C. The Stage 1 Disinfectant
- D. None of the above

Stage 2 DBP Rule Federal Register Notices

80. Which of the following rules is one part of the Microbial and Disinfection Byproducts Rules, which are a set of interrelated regulations that address risks from microbial pathogens and disinfectants/disinfection byproducts?

- A. Groundwater Rule (GWR)
- B. The Stage 2 DBP rule
- C. Long Term 2 Enhanced Surface Water Treatment Rule (LT2)
- D. None of the above

81. Which of the following rules focuses on public health protection by limiting exposure to DBPs, specifically total trihalomethanes and five haloacetic acids, which can form in water through disinfectants used to control microbial pathogens?

- A. Stage 1 DBPR
- B. The Stage 2 DBP rule
- C. Long Term 2 Enhanced Surface Water Treatment Rule
- D. None of the above

82. The Stage 2 DBP rule will apply to all community water systems and nontransient non-community water systems that add a primary or residual disinfectant other than chloramines or deliver water that has been disinfected by a primary or residual disinfectant other than chloramines.

- A. True
- B. False

83. Which of the following rules has been highly effective in protecting public health and has also evolved to respond to new and emerging threats to safe drinking water?

- A. Stage 2 DBPR
- B. Safe Drinking Water Act (SDWA)
- C. Surface Water Treatment Rule
- D. None of the above

84. Which of the following terms is one of the major public health advances in the 20th century?

- A. Major public health advances
- B. Disinfection of drinking water
- C. Amendments to the SDWA in 1996
- D. None of the above

85. Which of the following rules and the Long Term 2 Enhanced Surface Water Treatment Rule are the second phase of rules required by Congress?

- A. The Stage 2 DBPR
- B. This final rule
- C. Primary or residual disinfectant
- D. None of the above

86. Which of the following rules will reduce potential cancer and reproductive and developmental health risks from disinfection byproducts?

- A. DBP exposure
- B. Stage 2 Disinfection Byproducts Rule
- C. Traditional disinfection practices
- D. None of the above

87. Stage 2 Disinfection Byproducts Rule strengthens public health protection for customers by tightening _____ for two groups of DBPs, trihalomethanes and haloacetic acids.

- A. Primary or residual disinfectant
- B. Major public health advances
- C. Compliance monitoring requirements
- D. None of the above

Are THMs and HAAs the only disinfection byproducts?

88. The presence of _____ is representative of the occurrence of many other chlorination DBPs; thus, a reduction in the TTHM and HAA5 generally indicates a reduction of DBPs from chlorination.

- A. Chlorine and chloramine
- B. Classes of DBPs
- C. TTHM and HAA5
- D. None of the above

Chlorine By-Products

89. The most common chlorination by-products found in U.S. drinking water supplies are?

- A. Chlorate and Chlorite
- B. Trihalomethanes (THMs)
- C. Ammonia and THMS
- D. None of the above

The Principal Trihalomethanes are:

90. Chloroform, bromodichloromethane, chlorodibromomethane, and bromoform. Other less common chlorination by-products include the haloacetic acids and haloacetonitriles. The amount of THMs formed in drinking water can be influenced by a number of factors, including the season and the source of the water.

- A. True
- B. False

91. THM concentrations are generally higher in winter than in summer, because concentrations of natural organic matter are greater and more chlorine is required to disinfect at colder temperatures.

- A. True
- B. False

92. THM levels are also low when wells or large lakes are used as the drinking water source, because organic matter concentrations are generally low in these sources.

- A. True
- B. False

Health Effects

93. The available studies on health effects do not provide conclusive proof of a relationship between exposure to THMs and cancer or reproductive effects, but indicate the need for further research to confirm their results and to assess the potential health effects of chlorination by-products other than THMs.
- A. True B. False

Risks and Benefits of Chlorine

94. Many cities utilize the use ozone to disinfect their source water and to reduce formation of this parameter?
- A. Chlorate and Chlorite C. Chloramines
B. Trihalomethanes (THMs) D. None of the above
95. _____ is a highly effective disinfectant, it breaks down quickly, so that small amounts of _____ or other disinfectants must be added to the water to ensure continued disinfection as the water is piped to the consumer's tap.
- A. Ozone, Chlorine C. Chlorine Dioxide, Chlorine
B. Chlorite, Chlorine D. None of the above
96. Modifying water treatment facilities to use _____ can be expensive, and _____ treatment can create other undesirable by-products that may be harmful to health if they are not controlled (e.g., bromate).
- A. Ozone, Chlorine C. Ozone, Ozone
B. Chlorite, Chlorine D. None of the above
97. Which term is a weaker disinfectant than chlorine, especially against viruses and protozoa; however, they are very persistent and, as such, can be useful for preventing re-growth of microbial pathogens in drinking water distribution systems?
- A. UV C. Chloramines
B. Chlorite D. None of the above
98. Chlorine dioxide can be an effective disinfectant, but it forms?
- A. Chlorate and Chlorite C. Chloramines
B. THMS D. None of the above

Water Chemistry Section

pH Testing Section

99. When an atom loses _____ and thus has more protons than electrons, the atom is a positively-charged ion or cation.
- A. A proton C. An electron
B. Charge D. None of the above
100. Pure water has a pH very close to?
- A. 7 C. 7.7
B. 7.5 D. None of the above

101. _____ are determined using a concentration cell with transference, by measuring the potential difference between a hydrogen electrode and a standard electrode such as the silver chloride electrode.
- A. Primary pH standard values C. pH measurement(s)
 B. Alkalinity D. None of the above
102. Mathematically, pH is the negative logarithm of the activity of the (solvated) hydronium ion, more often expressed as the measure of the?
- A. Electron concentration C. Hydronium ion concentration
 B. Alkalinity concentration D. None of the above
103. Which of the following terms for aqueous solutions can be done with a glass electrode and a pH meter, or using indicators?
- A. Primary sampling C. Determining values
 B. Measurement of pH D. None of the above
104. The pH scale is logarithmic and therefore pH is?
- A. An universal indicator C. An excess of alkaline earth metal concentrations
 B. A dimensionless quantity D. None of the above
105. pH is defined as the decimal logarithm of the reciprocal of the _____, a_{H^+} , in a solution.
- A. Hydrogen ion activity C. Brønsted–Lowry acid–base theory
 B. Acid-base behavior D. None of the above
106. Which of the following terms may be used to measure pH, by making use of the fact that their color changes with pH?
- A. Indicators C. A set of non-linear simultaneous equations
 B. Spectrophotometer D. None of the above
107. Alkalinity is the name given to the quantitative capacity of an aqueous solution to neutralize an?
- A. Acid C. Bond formation
 B. Base D. None of the above
108. Under normal circumstances this means that the concentration of hydrogen ions in acidic solution can be taken to be equal to the concentration of the acid. The pH is then equal to minus the logarithm of?
- A. The concentration value C. A set of non-linear simultaneous equations
 B. The pH D. None of the above
109. Alkalinity of water is its acid-neutralizing capacity. It is the sum of all the titratable bases. The measured value may vary significantly with the?
- A. End-point pH C. pH measurement(s)
 B. Alkalinity D. None of the above
110. For strong acids and bases no calculations are necessary except in extreme situations. The pH of a solution containing a weak acid requires the solution of a quadratic equation. The pH of a solution containing a weak base may require the?
- A. Solution of a cubic equation C. Excess of alkaline earth metal concentrations
 B. Non-linear simultaneous equations D. None of the above

111. Since pH is a logarithmic scale, a difference of one pH unit is equivalent to _____ difference in hydrogen ion concentration

- A. 1 C. 10
B. .1 D. None of the above

Halogens- Halides

112. What is the negative ion often referred to as?

- A. A halide proton C. Diatomic Compound
B. A halide ion D. None of the above

113. Which of the following terms contains ions known as halides?

- A. Salts C. Hydrastatic acid
B. Organic halides D. None of the above

114. Halide ions combined with single hydrogen atoms form the hydrohalic acids (i.e., HF, HCl, HBr, HI), a series of particularly strong acids, one being?

- A. Salts C. Hydrastatic acid
B. Organic halides D. None of the above

115. Many synthetic organic compounds such as plastic polymers, and a few natural ones, contain halogen atoms; these are known as halogenated compounds or?

- A. Salts C. Hydrastatic acid
B. Organic halides D. None of the above

Chlorine

116. The only halogen is needed in relatively large amounts (as chloride ions) by humans?

- A. Chlorine C. Fluoride
B. Iodine D. None of the above

117. This halogen is needed only in very small amounts for the production of thyroid hormones such as thyroxine?

- A. Chlorine C. Fluoride
B. Iodine D. None of the above

118. On the other hand, neither fluorine nor bromine are believed to be really essential for humans, although small amounts of _____ can make tooth enamel resistant to decay.

- A. Chlorine C. Fluoride
B. Iodine D. None of the above

Alternative Disinfection Section

Chlorine Dioxide Section

119. ClO₂ generation uses _____ and chlorine gas.

- A. Sodium chlorite (NaClO₂) C. Ozone
B. Hypochlorous acid D. None of the above

120. Chlorine gas is educted into a motive water stream in a ClO₂ generator forming?

- A. HOCl and HCl C. Sodium thiosulfate
B. Chlorine dioxide D. None of the above

121. Which compound is pumped into the stream and allowed to react in a generating column to produce ClO_2 ?
- A. Hypochlorous acid C. Sodium chlorite
B. Chlorine dioxide D. None of the above
122. Which of the following compound(s) does not hydrolyze in water as chlorine does and with it, no dissociation of ClO_2 ?
- A. Chlorine gas C. NaOCl and HCl
B. Chlorine dioxide or ClO_2 D. None of the above
123. Which of the following compound(s) remains a gas in water, it does not have the corrosive tendencies of chlorine gas?
- A. Sodium chlorite (NaClO_2) C. Sodium chlorate (NaClO_3)
B. Chlorine dioxide or ClO_2 D. None of the above
124. Which of the following compound(s) is a dissolved gas in water; there is no mineral acid or caustic soda formation as happens when using HOCl .
- A. ClO_2 C. NaOCl and HCl in place of chlorine gas
B. NaClO_2 D. None of the above
125. Which of the following compound(s) tends to be much less, if not totally non-reactive, with many organic and inorganic compounds.
- A. ClO_2 C. Sodium chlorite (NaClO_2)
B. Hypochlorous acid D. None of the above
126. Which of the following compound(s) is much less aggressive to traditional corrosion inhibitors?
- A. Chlorine gas C. NaOCl and HCl
B. Chlorine dioxide or ClO_2 D. None of the above
127. Which compound is a yellow-green gas with an irritating odor not unlike Chlorine?
- A. Chlorine C. Ozone
B. Chlorine dioxide D. None of the above
128. Which compound cannot be compressed and shipped in a container, so it must be generated on site?
- A. Sodium thiosulfate C. Sodium chlorate (NaClO_3)
B. Chlorine dioxide D. None of the above
129. Which of the following compound(s) under efficient generation, THMs are not formed and THM precursor(s) are reduced. In one application, THM formation was reduced from 34 m g/l to 1 m g/l?
- A. ClO_2 C. Sodium chlorate (NaClO_3) and sulfuric acid
B. NaClO_2 D. None of the above
130. Which of the following compound(s) is formed from the dissolution of chlorine gas or sodium hypochlorite in water, has satisfactorily controlled microorganisms in cooling water systems?
- A. Hydrochlorous acid C. Hypochlorous Acid
B. Chlorine gas D. None of the above

131. The effects of _____ on hypochlorous acid and its reactivity with a variety of compounds both combine to vastly diminish its effectiveness in contaminated, high-pH cooling water systems.

- A. THM precursor(s)
- B. Chlorine dioxide
- C. pH
- D. None of the above

Ultraviolet Disinfection

132. The microorganisms spend maximum time and contact with the outside of the quartz tube and the source of the?

- A. UV rays
- B. Radiation
- C. Electromagnetic energy
- D. None of the above

133. The basic design flow of water of certain UV units is in the order of _____ for each inch of the lamp, the units are designed so that the contact or retention time of the water in the unit is not less than _____.

- A. 20 gpm - 15 seconds
- B. 2.0 gpm - 100 seconds
- C. 2.0 gpm - 15 seconds
- D. None of the above

134. A disinfection process involves exposing water to _____, which inactivates various microorganisms. The technique has enjoyed increased application in wastewater treatment but very limited application in potable water treatment.

- A. Sterilizer
- B. Electromagnetic energy
- C. Ultraviolet (UV) radiation
- D. None of the above

135. In UV, quartz is often used in this case since practically none of the UV rays are absorbed by the quartz, _____ cannot be used since it will absorb the UV rays, leaving little for disinfection.

- A. Carbon
- B. Ozone
- C. Ordinary glass
- D. None of the above

136. The _____ will consist of a various number of lamps and tubes, depending upon the quantity of water to be treated.

- A. UV sterilizer
- B. Electromagnetic energy
- C. UV reactor
- D. None of the above

137. Ensuring that the _____ maintains good contact with the water requires control of the water level within the channel to ensure that the UV is making total contact at the designed depths.

- A. UV
- B. Ballasts and shields
- C. Channel
- D. None of the above

138. Heat is generated by the electric components of the UV system, adequate ventilation and cooling must be applied to the _____ to reduce heat build-up, otherwise the ballasts could fail.

- A. UV arrays
- B. Electromagnetic energy
- C. UV reactor
- D. None of the above

139. Because of the great electrical consumption of this system, combined with the cost of routine replacement of _____, should be considered against other systems.

- A. UV capacitor
- B. UV Flux
- C. Ballasts and shields
- D. None of the above

140. Which term represents the transfer of electromagnetic energy from a mercury arc lamp to a pathogen's DNA material, thus affecting its ability to replicate itself?
A. Transfer C. Electromagnetic energy
B. UV disinfection D. None of the above

141. Which term represents the intensity being emitted, the length of time that the wastewater comes in contact with the UV radiation, and the arrangement of the UV reactor?
A. UV radiation C. CT
B. Disinfection D. None of the above

Strongest Oxidizing Agent

142. Which compound is obtained by passing a flow of air or oxygen between two electrodes that are subjected to an alternating current in the order of 10,000 to 20,000 volts?
A. Liquid Ozone C. O₂
B. Ozone D. None of the above

143. Ozone is a _____ gas at room temperature.
A. Reddish C. Light blue
B. Yellowish D. None of the above

144. Ozone has a _____ similar to that sometimes noticed during and after heavy electrical storms. In use, ozone breaks down into oxygen and nascent oxygen.
A. Self-policing pungent odor C. Pleasant odor of rain
B. H₂S odor D. None of the above

145. Ozone does not form chloramines or _____, and while it may destroy some THMs, it may produce others when followed by chlorination.
A. Carcinogens C. Oxygen and nascent oxygen
B. THMs D. None of the above

146. Ozone falls into the same category as other disinfectants in that it can produce?
A. Carcinogens C. Oxygen and nascent oxygen
B. DBPs D. None of the above

147. It is the nascent oxygen that produces the high oxidation and disinfections, and even sterilization. Each water has its own _____, in the order of 0.5 ppm to 5.0 ppm. Contact time, temperature, and pH of the water are factors to be determined.
A. Nascent oxygen C. Ozone demand
B. THMs D. None of the above

148. Liquid Ozone is very unstable and can readily explode. As a result, it is not shipped and must be manufactured on-site.
A. True B. False

149. Ozone is a very effective disinfectant for both Giardia and viruses
A. True B. False

150. Ozone does not produce chlorinated byproducts (such as trihalomethanes) but it may cause an increase in such byproduct formation if it is fed ahead of free chlorine; ozone may also produce its own oxygenated byproducts such as Cl₂ + NH₄.
A. True B. False

151. Ozonation must include adequate ozone leak detection alarm systems, and an ozone off-gas destruction system.

- A. True B. False

152. When determining Ozone CT (contact time) values must be determined for the ozone basin alone; an accurate _____ must be obtained for the contact chamber, and residual levels.

- A. Residual C. Contact time
B. T10 value D. None of the above

153. Ozone does not provide a system residual and should be used as a primary disinfectant only in conjunction with?

- A. Dry sodium chlorite C. Free and/or combined chlorine
B. Chlorine dioxide D. None of the above

Alternate Disinfectants Section Summary

Chloramines

154. It is recommended that Chloramine be used in conjunction with a stronger disinfectant. It is best utilized as a?

- A. Chloramine C. Stable distribution system disinfectant
B. T10 value disinfectant D. None of the above

155. In the production of _____, the ammonia residuals in the finished water, when fed in excess of stoichiometric amount needed, should be limited to inhibit growth of nitrifying bacteria.

- A. Dry sodium chlorite C. Ammonia residual(s)
B. Chloramines D. None of the above

Chlorine Dioxide

156. Which term provides good Giardia and virus protection but its use is limited by the restriction on the maximum residual of 0.5 mg/L ClO_2 /chlorite/chlorate allowed in finished water?

- A. Chlorinated byproducts C. Ammonia residual(s)
B. Chlorine dioxide D. None of the above

157. If chlorine dioxide is being used as an oxidant, the preferred method of generation is to entrain this term or substance into a packed reaction chamber with a 25% aqueous solution of sodium chlorite (NaClO_2).

- A. Chloramine C. Chlorine dioxide
B. Chlorine gas D. None of the above

158. According to the text, which chemical is explosive and can cause fires in feed equipment if leaking solutions or spills are allowed to dry out?

- A. Dry sodium chlorite C. Ammonia
B. Chlorine dioxide D. None of the above

159. Chlorine dioxide may be used for either taste or odor control or as a?

- A. Chloramine C. Gas
B. Pre-disinfectant D. None of the above

Ozone

160. Which term must be determined for the ozone basin alone; an accurate T10 value must be obtained for the contact chamber, residual levels measured through the chamber and an average ozone residual calculated?

- A. Ozone CT (Contact time)
- B. Residual levels
- C. Free and/or combined chlorine
- D. None of the above

161. Ozone may also be used as _____ for removal of taste and odor, or may be applied as a pre-disinfectant.

- A. An oxidant
- B. Reducer
- C. System residual
- D. None of the above

Chlorine Section

Chlorine Gas Appearance and Odor

162. Chlorine is a greenish-yellow gas it will condense to an amber liquid at about _____°F or at high pressures.

- A. 32 degrees
- B. -29.2 degrees
- C. 29 degrees
- D. None of the above

163. Lengthy exposures to chlorine gas may result in _____. Odor thresholds ranging from 0.08 to part per million (ppm) parts of air have been reported.

- A. Exposure to chlorine
- B. Odor thresholds
- C. Olfactory fatigue
- D. None of the above

Reactivity

164. Cylinders of chlorine may burst when exposed to elevated temperatures. When there is Chlorine in solution, this forms?

- A. Hydrogen sulfide
- B. Oxomonosilane
- C. A corrosive material
- D. None of the above

165. What is formed when chlorine is in contact with combustible substances (such as gasoline and petroleum products, hydrocarbons, turpentine, alcohols, acetylene, hydrogen, ammonia, and sulfur), reducing agents, and finely divided metals?

- A. Fires and explosions
- B. Odor thresholds
- C. Moisture, steam, and water
- D. None of the above

166. Chlorine reacts with hydrogen sulfide and water to form which substance?

- A. Hydrogen sulfide
- B. Hydrochloric acid
- C. Chlorinates
- D. None of the above

167. Chlorine is also incompatible with?

- A. Plastic
- B. Palladium
- C. Moisture, steam, and water
- D. None of the above

Flammability

168. When there is a fire that involves chlorine, the firefight should be fought downwind from the minimum distance possible.

- A. True
- B. False

169. Keep unnecessary people away; isolate the hazard area and deny entry. For a massive fire in a cargo area, use unmanned hose holders or monitor nozzles; if this is impossible, withdraw from the area and let the fire burn. Emergency personnel should stay out of low areas and ventilate closed spaces before entering.

- A. True B. False

What Happens to Chlorine When it Enters the Environment?

170. When chlorine is released to soil, chlorine will react with moisture forming free unstable oxygen radicals.

- A. True B. False

171. The hydrochloric acid will raise the pH of the water (makes it more basic).

- A. True B. False

172. When released to air, chlorine will react with water to form hypochlorous acid and hydrochloric acid, which are easily removed from the atmosphere by generation of free oxygen radicals.

- A. True B. False

Chlorine Exposure Limits

173. The current Occupational Safety and Health Administration (OSHA) permissible exposure limit (PEL) for chlorine is 10 PPM (3 milligrams per cubic meter (mg/m^3)) as a ceiling limit. A worker's exposure to chlorine shall at no time exceed this ceiling level.

- A. True B. False

174. Chlorine's Physical and chemical properties: A yellowish green, nonflammable and liquefied gas with an unpleasant and irritating smell.

- A. True B. False

175. OSHA PEL is?

- A. 10 PPM C. 1,000 PPM
B. 1 PPM D. None of the above

176. Chlorine can be readily compressed into a clear, amber-colored liquid, a _____, and a strong oxidizer.

- A. Combustible gas C. Noncombustible gas
B. Combustible liquid D. None of the above

177. Liquid chlorine is about _____ times heavier than water and gaseous chlorine is about 2.5 times heavier than air.

- A. 1.5 C. 2.5
B. 0.5 D. None of the above

178. Cl_2 IDLH is?

- A. 10 PPM C. 1,000 PPM
B. 0.1 PPM D. None of the above

179. Cl_2 fatal exposure limit is?

- A. 10 PPM C. 1,000 PPM
B. 0.1 PPM D. None of the above

Disinfectant Qualities

180. Chlorine is so important in poultry processing that the US Department of Agriculture requires an almost constant chlorine rinse for much of the cutting equipment. In fact, no proven economical alternative to chlorine disinfection exists for use in Meat and poultry processing facilities.

- A. True B. False

Properties

181. Because it is highly reactive, chlorine is usually found in nature bound with other elements like sodium, potassium, and magnesium.

- A. True B. False

182. In researching and synthesizing organic compounds some compounds that have at least one atom of the element carbon in their molecular structure. All living organisms, including humans, are composed of primarily of _____.

- A. Organic compounds C. Inorganic compounds
B. Abundant chemical elements D. None of the above

183. What is a largest reservoir of dissolved chlorine weathered from the continents and transported to the oceans by Earth's rivers?

- A. Brine C. Ancient seawater
B. Seawater D. None of the above

184. Chemical elements have their own set of unique properties and chlorine is known as _____--so reactive, in fact, that it is usually found combined with other elements in the form of compounds.

- A. Synthesizing organic compound C. One of the most abundant chemical elements
B. A very reactive element D. None of the above

185. Various states of chlorine includes when chlorine is isolated as a free element, chlorine is a greenish yellow gas, which is _____. It turns to a liquid state at -34°C (-29°F), and it becomes a yellowish crystalline solid at -103°C (-153°F).

- A. 2.5 times heavier than water C. 2.5 times heavier than air
B. 2.5 times lighter than air D. None of the above

Chlorine Gas Introduction

186. When chlorine is added into the water stream, chlorine hydrolyzes into?

- A. HCL C. Hypochlorous acid (HOCl), and hydrochloric acid (HCl)
B. Bromoform D. None of the above

187. When chlorine hydrolyzation occurs, it provides an active toxicant, _____, which is pH-dependent. In alkaline cooling systems, it readily dissociates to form the hypochlorite ion (OCl^-).

- A. HCl C. The hypochlorate ion (OCl^-)
B. HOCl D. None of the above

188. In alkaline conditions, _____ becomes the predominant species and lacks the biocidal efficacy of the non-dissociated form.

- A. HCl C. OCl^-
B. HOCl D. None of the above

189. Considerably more _____ is present at a pH of 7.0 than at pH 8.5.

- A. HCl
- B. HOCl
- C. OCl⁻
- D. None of the above

190. Chlorine can be non-selective, making it very sensitive to contamination from either cooling water makeup or from in-plant process leaks. _____, organic acids and organic compounds, sulfides, iron and manganese all easily react with HOCl.

- A. Ammonia
- B. Sodium hypochlorite
- C. Chlorine gas
- D. None of the above

191. What is the term that best describes the amount of chlorine needed to react with contamination species and it must be satisfied before active HOCl is available to provide a free chlorine residual?

- A. Chlorine demand
- B. Hypochlorite ion (OCl⁻)
- C. Total residual
- D. None of the above

192. Which of the following removes alkalinity, pH depression and system corrosion could occur?

- A. HCl
- B. HOCl
- C. pH of 7.0 than at pH 8.5
- D. None of the above

193. The combination of high chlorine demand in process-contaminated systems and the dissociation process in alkaline systems creates the need for greater chlorine feed to obtain the same microbial efficacy. This results in a higher concentration of HCl in the cooling system.

- A. True
- B. False

194. The chloride ion (Cl⁻) cannot damage or penetrate the passive oxide layer, leading to localized damage of the metal surface as does Hypochlorous acid (HOCl), and hydrochloric acid (HCl).

- A. True
- B. False

195. High chlorine concentrations have also been shown to directly attack traditional organic-based corrosion inhibitors. When these inhibitors are "deactivated," the metal surface would then be susceptible to corrosion. Process Safety Management (PSM) guidelines dictated by the U.S. Occupational Safety and Health Administration (OSHA), discharge problems related to Chlorinated organic compounds such as trihalomethane (THM), dezincification of admiralty brass and delignification of cooling tower wood are other significant concerns associated with the use of chlorine.

- A. True
- B. False

Chlorine Gas

Pathophysiology

196. As far as chlorine safety and respiratory protection, the intermediate _____ of chlorine accounts for its effect on the upper airway and the lower respiratory tract.

- A. Effects of Hydrochloric acid
- B. Vapor from Chlorine gas
- C. Water solubility
- D. None of the Above

197. Respiratory exposure to _____ may be prolonged because its moderate water solubility may not cause upper airway symptoms for several minutes.

- A. Hydrochloric acid
- B. Chlorine gas
- C. Plasma exudation
- D. None of the Above

198. The odor threshold for chlorine gas is approximately?

- A. 0.3-0.5 parts per million (ppm)
- B. 3 parts per million (ppm)
- C. 3-5 parts per million (ppm)
- D. None of the Above

Mechanism of Activity

199. The mechanisms of cellular injury are believed to result from the oxidation of functional groups in cell components, from reactions with tissue water to form _____, and from the generation of free oxygen radicals.

- A. Generation of free oxygen radicals
- B. Chlorine acid
- C. Hypochlorous and hydrochloric acid
- D. None of the above

Solubility Effects

200. Which of the following is highly soluble in water?

- A. Hydrochloric acid
- B. H_2SO_4
- C. Hypochlorous base
- D. None of the above

201. Because it is highly water soluble, Hypochlorous acid has an injury pattern similar to?

- A. Hydrochloric acid
- B. H_2SO_4
- C. Ferric acid
- D. None of the above

202. Which of the following may account for the toxicity of elemental chlorine and hydrochloric acid to the human body?

- A. Hydrochloric acid
- B. H_2SO_4
- C. Hypochlorous acid
- D. None of the above

Early Response to Chlorine Gas

203. If you mix ammonia with chlorine gas, this compound reacts to form _____.

- A. Chloramine gas
- B. Chlorine gas
- C. Sulfuric gas
- D. None of the Above

204. The early response to the odor threshold for chlorine depends on the (1) concentration of chlorine gas, (2) duration of exposure, (3) water content of the tissues exposed, and (4) individual susceptibility.

- A. True
- B. False

Pathological Findings

205. Chlorine is a highly reactive gas.

- A. True
- B. False

206. Chlorine gas is greenish yellow in color and very toxic. It is heavier than air and will therefore sink to the ground if released from its container. It is the toxic effect of Chlorine gas that makes it a good disinfectant, but it is toxic to more than just waterborne pathogens; it is also toxic to humans. It is a respiratory irritant and it can also irritate skin and mucus membranes.

- A. True
- B. False

207. Chlorine gas is sold as a compressed liquid, which is amber in color. Chlorine, as a solid, is heavier (less dense) than water. If the chlorine liquid is released from its container it will quickly return back to its liquid state.

- A. True
- B. False

208. Chlorine gas is the most expensive form of chlorine to use. The typical amount of chlorine gas required for water treatment is 1-16 mg/L of water. Different amounts of chlorine gas are used depending on the quality of water that needs to be treated. If the water quality is good, a higher concentration of chlorine gas will be required to disinfect the water if the contact time cannot be increased.

- A. True
- B. False

Chlorine's Effectiveness

209. The effectiveness of chlorination depends on the _____ of the water, the concentration of the chlorine solution added, the time that chlorine is in contact with the organism, and water quality.

- A. Chlorine residual
- B. Chlorine demand
- C. Breakpoint
- D. None of the above

210. Chlorine may not be accessible for disinfection because _____ in the water (like iron, manganese, hydrogen sulfide, and ammonia).

- A. pH increases
- B. Part of it combines with other chemicals
- C. Required contact time
- D. None of the above

211. The amount of chlorine required to attain disinfection and that reacts with the other chemicals is the?

- A. Chlorine residual
- B. Chlorine demand
- C. Free chlorine residual
- D. None of the above

212. Which term is used when disinfection decreases, as the concentration of the chlorine increases?

- A. Breakpoint
- B. Chlorine level
- C. Required contact time
- D. None of the above

213. Chlorination is more effective as?

- A. Water temperature increases
- B. Chlorine demand increases
- C. Water cools down
- D. None of the above

214. Chlorination becomes more alkaline and is less effective as the?

- A. Water's pH increases
- B. Water quality increases
- C. Required contact time is maximized
- D. None of the above

215. Chlorination is less effective in?

- A. Clear water
- B. Cloudy (turbid) water
- C. Day time
- D. None of the above

216. By adding a little more chlorine to what is already sufficient, this action will generally result in _____ that can be measured easily.

- A. pH increases
- B. A free chlorine residual
- C. Required contact time
- D. None of the above

Potent Germicide

217. Chlorine disinfectants can lower the level of many disease-causing microorganisms in drinking water to almost immeasurable levels.

- A. True
- B. False

218. Chlorine is added to drinking water to destroy pathogenic (disease-causing) organisms. It can be applied in several forms: sodium hypochlorite solution, elemental chlorine (chlorine gas) and dry calcium hypochlorite.

- A. True
- B. False

219. One pound of elemental chlorine delivers approximately as much _____ as one gallon of sodium hypochlorite (12.5% solution) or approximately 1.5 pounds of calcium hypochlorite (65% strength).

- A. Free available chlorine
- B. Total chlorine
- C. Particular applications
- D. None of the above

220. While any of these forms of chlorine can effectively disinfect drinking water, each has distinct advantages and limitations for _____. Almost all water systems that disinfect their water use some type of chlorine-based process, either alone or in combination with other disinfectants.

- A. Free available chlorine
- B. Total chlorine
- C. Particular applications
- D. None of the above

Taste and Odor Control

221. Chlorine disinfectants reduce many disagreeable tastes and odors. Chlorine oxidizes many naturally occurring substances such as _____, sulfides and odors from decaying vegetation.

- A. Hydrogen sulfide
- B. Foul-smelling algae secretions
- C. Slime bacteria, molds and algae
- D. None of the above

Biological Growth Control

222. Chlorine disinfectants eliminate _____ that commonly grow in water supply reservoirs, on the walls of water mains and in storage tanks.

- A. Hydrogen sulfide
- B. Foul-smelling algae secretions
- C. Slime bacteria, molds and algae
- D. None of the above

Chemical Control

223. Chlorine disinfectants destroy _____ (which has a rotten egg odor) and remove ammonia and other nitrogenous compounds that have unpleasant tastes and hinder disinfection. They also help to remove iron and manganese from raw water.

- A. Hydrogen sulfide
- B. Algae secretions
- C. Slime bacteria, molds and algae
- D. None of the above

Water Treatment

224. Generally speaking, water is treated to render it suitable for human use and consumption. While the primary goal is to produce a biologically (disinfected) and chemically safe product, other objectives also must be met, including: no objectionable taste or odor; _____ and chemical stability.

- A. Low levels of color and turbidity
- B. Sediments
- C. Chemical or biological contamination
- D. None of the above

225. Surface water typically presents a greater treatment challenge than groundwater, which is naturally filtered as it percolates through?

- A. Low levels of color and turbidity
- B. Sediments
- C. Chemical or biological contamination
- D. None of the above

Water Distribution

226. In the event of a significant intrusion of pathogens resulting, for example, from a broken water main, the level of the average "_____ " will be insufficient to disinfect contaminated water. In such cases, it is the monitoring of the sudden drop in the chlorine residual that provides the critical indication to water system operators that there is a source of contamination in the system.

- A. Chlorine residual
- B. Potential threats
- C. Breakpoint Chlorination
- D. None of the above

The Challenge of Disinfection Byproducts

227. Which of the following happens when chlorine and other disinfectants react with natural organic matter in water?

- A. Microbial contamination
- B. Treatment barrier
- C. Chemical compounds formed unintentionally
- D. None of the above

228. While the available evidence does not prove that _____ in drinking water cause adverse health effects in humans, high levels of these chemicals are certainly undesirable. Cost-effective methods to reduce DBP formation are available and should be adopted where possible.

- A. Critical assets
- C. Vulnerability assessments
- B. DBPs
- D. None of the above

Chlorine and Water System Security

229. With passage of the Public Health Security and Bioterrorism Response Act of 2002, Congress required community water systems to assess their vulnerability to a terrorist attack and other intentional acts. As part of these vulnerability assessments, systems assess?

- A. Microbial contamination
- C. The transportation, storage and use of treatment chemicals
- B. Cost-effective methods
- D. None of the above

230. These treatment chemicals are both inert and potential barriers.

- A. True
- B. False

231. The prospect of a terrorist attack has forced all water systems, large and small, to re-evaluate and upgrade chlorination effectiveness procedures.

- A. True
- B. False

232. Water systems using elemental chlorine, in particular, must determine whether existing protection systems are adequate. If not, they must consider additional measures to reduce the likelihood of an attack or to mitigate the?

- A. Potential consequences
- C. Critical assets
- B. Potential threats
- D. None of the above

233. Which of the following in no way guarantees safety from biological attacks?

- A. Inert and potential barriers
- C. Conventional treatment barriers
- B. Potential problems
- D. None of the above

Chlorination Chemistry

234. The hypochlorite ion is a much weaker disinfecting agent than Hypochlorous acid, about 100 times less effective.

- A. True
- B. False

235. Under normal water conditions, hypochlorous acid will also chemically react and break down into the hypochlorite ion.

- A. True
- B. False

236. pH and temperature affect the ratio of hypochlorous acid to hypochlorite ions. As the temperature is decreased, the _____ increases.

- A. CT actual
- C. Ratio of hypochlorous acid
- B. Free chlorine residual
- D. None of the above

237. The disassociation of chlorine gas

(OCI⁻): HOCl ⇌ H⁺ + OCl⁻ Also expressed HOCl → H⁺ + OCl⁻
(hypochlorous acid) (hydrogen) (hypochlorite ion)

- A. True
- B. False

238. All three forms of chlorine produce sodium hypochlorite when added to water.

- A. True
- B. False

239. Hypochlorous acid is a strong acid but a weak disinfecting agent. The amount of hypochlorous acid depends on the pH and temperature of the water.

- A. True
- B. False

240. Temperature plays a small part in the acid ratio. Although the ratio of _____ is greater at lower temperatures, pathogenic organisms are actually harder to kill.

- A. Hypochlorous acid
- B. Chlorine Demand
- C. Total chlorine
- D. None of the above

241. If all other things were equal, _____ and a lower pH are more conducive to chlorine disinfection.

- A. Lower alkali
- B. Higher water temperatures
- C. Lower water temperature
- D. None of the above

Types of Residual

242. Total chlorine residual = free + _____.

- A. Chlorine demand
- B. Free chlorine
- C. Combined chlorine residual
- D. None of the above

243. In water, there are always other substances (interfering agents) such as iron, manganese, turbidity, etc., which will combine chemically with the chlorine, this is called the?

- A. Chlorine demand
- B. Free chlorine
- C. Combined chlorine residual
- D. None of the above

244. According to the text, once chlorine molecules are combined with these interfering agents, they are not capable of disinfection. _____ is much more effective as a disinfecting agent.

- A. Chlorine demand
- B. Free chlorine
- C. Combined chlorine residual
- D. None of the above

245. Either a total or a _____ can be read when a chlorine residual test is taken,

- A. Chlorine demand
- B. Free chlorine residual
- C. Combined chlorine residual
- D. None of the above

246. Which of the following is a much stronger disinfecting agent, therefore, most water regulating agencies will require that your daily chlorine residual readings be of free chlorine residual?

- A. Chlorine demand
- B. Free chlorine residual
- C. Combined chlorine residual
- D. None of the above

247. Which of the following terms is where the chlorine demand has been satisfied, and any additional chlorine will be considered free chlorine?

- A. Chlorine residual
- B. "CT" disinfection concept
- C. Break-point chlorination
- D. None of the above

Residual Concentration/Contact Time (CT) Requirements

248. Since monitoring for very low levels of pathogens in treated water is analytically very difficult, utilizing the _____ is recommended to demonstrate satisfactory treatment.

- A. Chlorine residual
- B. "CT" disinfection concept
- C. Break-point chlorination
- D. None of the above

249. Which of the following term = Concentration (mg/L) x Time (minutes)

- A. CT
- B. #C
- C. TC
- D. None of the above

250. When changing the Cl₂ cylinder, clean with wire brush if necessary. If the valve face is smooth, clean proceed with hooking up the cylinder. Check the inlet face of the _____ and clean if necessary.

- A. Fusible plug
- B. Chlorine cylinder
- C. Chlorinator
- D. None of the above

251. What is the best term that describes chlorine addition of chlorine at the plant headworks or prior to other water treatment or groundwater production processes and mainly used for disinfection and control of tastes, odors, and aquatic growth?

- A. Post-chlorination
- B. Chlorine Demand
- C. Pre-chlorination
- D. None of the above

252. What term best describes the sum of free and combined chlorine?

- A. Disinfection
- B. Free chlorine
- C. Total Chlorine
- D. None of the above

253. When chlorinating most potable water supplies, total chlorine is essentially equal to _____ since the concentration of ammonia or organic nitrogen compounds (needed to form combined chlorine) will be very low.

- A. The amount of chlorine
- B. Chlorine Demand
- C. Free chlorine
- D. None of the above

254. What term best describes the residual chlorine existing in water in chemical combination with ammonia or organic amines that can be found in natural or polluted waters?

- A. Combined chlorine
- B. Free chlorine
- C. Breakpoint chlorination
- D. None of the above

255. Ammonia is sometimes deliberately added to chlorinated public water supplies to provide?

- A. Inorganic chloramines
- B. Chlorine Demand
- C. Increase pH value
- D. None of the above

256. What term best describes the concentration of residual chlorine in water present as dissolved gas (Cl₂), hypochlorous acid (HOCl), and/or hypochlorite ion (OCl⁻)?

- A. Disinfection
- B. Free chlorine
- C. Total chlorine residual
- D. None of the above

257. What term best describes the minimum amount of chlorine needed to react in a water purification system; used as a monitoring measurement by system operators?

- A. Chlorination
- B. Chlorine Demand
- C. Total chlorine
- D. None of the above

258. What term best describes the concentration of chlorine in the water after the chlorine demand has been satisfied?

- A. Chlorine Residual
- B. Free chlorine
- C. Breakpoint chlorination
- D. None of the above

259. _____ which includes both the free and combined or chemically bound chlorine residuals.

- A. Disinfection
- B. Free chlorine
- C. Total chlorine residual
- D. None of the above

260. What term best describes the addition of chlorine after a process or adding chlorine downstream to meet a Demand in the system?

- A. Post-chlorination
- B. Chlorine Demand
- C. Pre-chlorination
- D. None of the above

261. Solid chlorine is about 10 times heavier than water and gaseous chlorine is about 200 times heavier than air.

- A. True
- B. False

Sodium Hypochlorite Exposure

262. There is no threshold value for to sodium hypochlorite exposure. Various health effects occur after exposure to sodium hypochlorite. People are exposed to sodium hypochlorite by inhalation of aerosols. This causes coughing and a sore throat. After swallowing sodium hypochlorite, the effects are stomachache, a burning sensation, coughing, diarrhea, a sore throat and vomiting. Sodium hypochlorite on skin or eyes causes redness and pain.

- A. True
- B. False

263. After prolonged exposure, the skin can become sensitive. Sodium hypochlorite is poisonous for water organisms. It is mutagenic and very toxic when it comes in contact with Ammonium salts.

- A. True
- B. False

Routes of Exposure

Inhalation

264. Chlorine is lighter than air and may cause asphyxiation in poorly ventilated, enclosed, or high-lying areas.

- A. True
- B. False

Ingestion

265. Metabolic acidosis is rare, but has been reported following the ingestion of?

- A. Hypochlorous Acid (HOCl)
- B. Household bleach
- C. Sodium and calcium
- D. None of the above

Sources/Uses

266. Which compounds are manufactured by the chlorination of sodium hydroxide or lime?

- A. Sodium hypochlorite
- B. Sodium and calcium hypochlorite
- C. Hypochlorite solutions, powder, or concentrated vapor
- D. None of the above

267. Which compounds are used primarily as oxidizing and bleaching agents or disinfectants? They are components of commercial bleaches, cleaning solutions, and disinfectants for drinking water and waste water purification systems and swimming pools.

- A. Sodium hydroxide or lime
- B. Hydrochlorite solutions
- C. Sodium and calcium hypochlorite
- D. None of the above

Calcium Hypochlorite Section

268. Which of the following substances comes in two forms: powder and tablets?

- A. Calcium hypochlorite
- B. Hypochlorous Acid (HOCl)
- C. Sodium hypochlorite
- D. None of the above

269. Sodium hypochlorite is generally available as a white powder, pellets, or flat plates; sodium hypochlorite is usually a greenish yellow, aqueous solution, although not flammable, they may react explosively.

- A. True B. False

270. Calcium hypochlorite decomposes in water to release chlorine and oxygen; sodium hypochlorite solutions can react with acids or ammonia to release chlorine or chloramine.

- A. True B. False

Description

271. Solid chlorine stands alone as the safest form of chlorine disinfection.

- A. True B. False

272. Solid chlorine requires only minimal safety equipment for handling; users can breathe easy knowing our tablets are safe for both people and the environment.

- A. True B. False

273. Because of solid chlorine, the elimination of costly scrubbers, containment, or hazard response capability, guarantees lower initial costs and reduced operating expense.

- A. True B. False

274. Sodium hypochlorite is generally available as a white powder, pellets, or flat plates. It decomposes readily in water or when heated, releasing oxygen and chlorine. It has a strong chlorine odor, but odor may not provide an adequate warning of hazardous concentrations.

- A. True B. False

275. Calcium hypochlorite is flammable, and acts as an oxidizer with combustible material and does not react explosively with ammonia, amines, or organic sulfides.

- A. True B. False

Accuracy

276. Which compound's strengths vary so widely and are mostly unknown (the container usually says "less than 5%") that it is impossible to make up accurate in-use solutions without access to laboratory equipment?

- A. Liquid chlorine C. Calcium hypochlorite
B. Solid chlorine D. None of the above

Effectiveness

277. Liquid Sodium hypochlorite and chlorine tablets produce Hypochlorous acid (HOCl) and?

- A. Calcium hypochlorite C. Hypochlorite ion (OCl⁻) in solution
B. Oxygen D. None of the above

278. The ratio of Hypochlorous Acid to _____ increases with acidity.

- A. Calcium hypochlorite C. Hypochlorite ion
B. Hypochlorous Acid (HOCl) D. None of the above

Comparison

279. Which substance is comparable to sodium dichloroisocyanurate (NaDCC) is their neutralization by organic matter.

- A. Hypochlorous Acid C. Sodium hypochlorite (NaOCl)
B. Chloramine D. None of the above

280. If there is a high concentration of organic material present, NaDCC will be very much more effective than?

- A. Calcium hypochlorite
- B. Oxygen and chlorine
- C. NaOCL
- D. None of the above

281. Hypochlorite powder, solutions, and vapors are irritating and corrosive to the eyes, skin, and respiratory tract.

- A. True
- B. False

282. Ingestion and skin contact with hypochlorite powder, solutions, and vapors produces injury to any exposed tissues.

- A. True
- B. False

283. Exposure to gases released from hypochlorite powder, solutions, and vapors may cause burning of the eyes, nose, and throat; cough as well as constriction and edema of the airway and lungs can occur.

- A. True
- B. False

Sodium Hypochlorite Solutions

284. Sodium hypochlorite solutions liberate the Toxic gases chlorine or chloramine if mixed with acid or ammonia (this can occur when bleach is mixed with another cleaning product). Thus, exposure to hypochlorite may involve exposure to these gases.

- A. True
- B. False

Potential Sequelae

285. Exposure to toxic gases generated from hypochlorite solutions can lead to reactive airways dysfunction syndrome (RADS), a chemical irritant-induced type of asthma.

- A. True
- B. False

286. Chronic complications following ingestion of hypochlorite include esophageal obstruction, pyloric stenosis, squamous cell carcinoma of the esophagus, and vocal cord paralysis with consequent airway obstruction.

- A. True
- B. False

Chlorine-Based Disinfectants Chloramines

Chloramine Disadvantages

287. Which residual in tap water can pass through membranes in dialysis machines and directly induce oxidant damage to red blood cells?

- A. Chloramine
- B. Dichloramine
- C. Ammonia and chlorine compounds
- D. None of the above

Chloramine Section

288. _____: $\text{NH}_3 + \text{HOCl} \rightarrow \text{NH}_2\text{Cl} + \text{H}_2\text{O}$

- A. Free chlorine
- B. Dichloramine
- C. Monochloramine
- D. None of the above

289. _____: $\text{NHCl}_2 + 3\text{HOCl} \rightarrow \text{NHCl}_3 + 3\text{H}_2\text{O}$

- A. Trichloramine
- B. Dichloramine
- C. Ammonia and chlorine compounds
- D. None of the above

290. Free chlorine reacts with the chloramine to produce hydrogen ion, water, and _____ which will come out of solution. In the case of the monochloramine, the following reaction occurs: $2\text{NH}_2\text{Cl} + \text{HOCl} \rightarrow \text{N}_2 + 6\text{HCl} + \text{H}_2\text{O}$

- A. Nitrogen gas
- B. Hydrogen
- C. Ammonia
- D. None of the above

291. _____: $\text{NH}_2\text{Cl} + 2\text{HOCl} \rightarrow \text{NHCl}_2 + 2\text{H}_2\text{O}$

- A. Trichloramine
- B. Dichloramine
- C. Ammonia and chlorine compounds
- D. None of the above

292. Which of the following terms are formed in the pH range of 4.5 to 8.5, however, monochloramine is most common when the pH is above 8?

- A. Trichloramine
- B. Dichloramine
- C. Monochloramine and dichloramine
- D. None of the above

Post Chlorination

293. Post chlorination is almost always done in water treatment, but can be replaced with chlorine dioxide or chloramines. In this stage, chlorine is fed to the drinking water stream which is then sent to the chlorine contact basin to allow the chlorine a long enough detention time to kill all viruses, bacteria, and protozoa that were not removed and rendered inactive in the prior stages of treatment.

- A. True
- B. False

294. Drinking water requires a large addition of chlorine because there must be a residual amount of chlorine in the water that will carry through the system until it reaches the tap of the user. After Post chlorination, the water is retained in a clear well prior to distribution.

- A. True
- B. False

Understanding Water Disinfection

Wastewater Disinfection

295. There are several chemicals and processes that will _____, but none are universally applicable as with chlorine.

- A. Limit the effects of organic material
- B. Limit the travel of pathogens
- C. Disinfect wastewater
- D. None of the above

Water Disinfection

296. Disinfection is usually the final stage in the water treatment process in order to limit the effects of organic material, suspended solids and _____.

- A. Organic material
- B. Other contaminants
- C. Residual level of disinfection
- D. None of the above

Chlorate Ion

297. Which of the following terms is predicted by VSEPR, about chlorate anions?

- A. Acid/base balance
- B. Stable perchlorates
- C. Trigonal pyramidal structures
- D. None of the above

298. Chlorates are powerful reducers and should be kept away from organics or easily oxidized materials.

- A. True
- B. False

299. _____ were once widely used in pyrotechnics, though their use has fallen due to their instability.

- A. Chlorates C. Chlorides
B. Perchlorates D. None of the above

Chloride Ion

300. The chloride ion is formed when elemental chlorine, gains an electron to form an anion (negatively-charged ion) Cl^- .

- A. True B. False

301. The salts of _____ contain chloride ions and can also be called chlorides.

- A. Hydrochloric acid C. Hypochlorous acid
B. H_2SO_4 D. None of the above

302. _____, more commonly called chloromethane, (CH_3Cl) is an organic covalently bonded compound, which does not contain a chloride ion.

- A. Chlorate C. Methyl chloride
B. Sodium chloride D. None of the above

303. Which of the following compounds is an example of table salt, which is sodium chloride with the chemical formula?

- A. CaCl_2 C. ClO_2^- .
B. NaCl D. None of the above

304. _____ is also the prosthetic group present in the amylase enzyme. Another example is calcium chloride with the chemical formula CaCl_2 .

- A. CaCl_2 C. ClO_4
B. A chloride ion D. None of the above

305. Which of the following compounds is used for maintaining unpaved roads and for sanite fortifying roadbases for new construction?

- A. CaCl_2 C. ClO_2^-
B. ClO_4 D. None of the above

306. Which of the following terms is also a useful and reliable chemical indicator of river / groundwater fecal contamination, as chloride is a non-reactive solute and ubiquitous to sewage & potable water?

- A. Chlorate C. Chlorine dioxide
B. Chloride D. None of the above

Chlorite Ion

307. The chlorite ion is?

- A. ClO_2^- C. ClO_3^- ,
B. ClO_4 D. None of the above

308. Chlorine can assume an additional oxidation state of +4 is seen in the neutral compound _____, which has a similar structure to chlorite ClO_2^- and the cation chloryl.

- A. Chlorine dioxide ClO_2 C. Chlorite ion of ClO_2^-
B. Chloride D. None of the above

Chlorine Dioxide

309. Chlorine dioxide is a chemical compound with which formula?

- A. CaCl_2
- B. ClO
- C. ClO_2
- D. None of the above

Haloacetic Acids

310. What type of substances are haloacetic acids in which a halogen atom takes the place of a hydrogen atom in acetic acid?

- A. Calcemic acids
- B. Hypochlorite acids
- C. Carboxylic acids
- D. None of the above

311. The inductive effect caused by the _____ often result in the higher acidity of these compounds by stabilizing the negative charge of the conjugate base.

- A. Carboxylic acids
- B. Disinfection by-products
- C. Electronegative halogens
- D. None of the above

Contaminants in Drinking Water

312. Which of the following terms expresses an exposure to such substances in drinking water has been associated with a number of health outcomes by epidemiological studies, although the putative agent in such studies has not been identified?

- A. Carboxylic acids
- B. Disinfection by-products
- C. Electronegative halogens
- D. None of the above

Hypochlorites

313. Hypochlorites are calcium or sodium salts of hypochlorous acid and are supplied either dry or in liquid form (as, for instance, in commercial bleach). The same residuals are obtained as with gas chlorine, but the effect on the _____ of the treated water is different.

- A. Temperature
- B. pH
- C. Negative charge
- D. None of the above

314. Hypochlorite compounds contain an excess of _____ and tend to raise the pH of the water.

- A. Acid
- B. Alkali
- C. Hypochlorite compounds
- D. None of the above

315. _____ is the only liquid hypochlorite disinfectant in current use. There are several grades and proprietary forms available.

- A. High-test calcium hypochlorite(s)
- B. Calcium hypochlorite tablets
- C. Sodium hypochlorite
- D. None of the above

Emergency Procedures

316. Emergency procedures in the case of a large uncontrolled chlorine leak: Notify local emergency response team, warn and evacuate people in adjacent areas, be sure that no one enters the leak area without adequate self-contained breathing equipment.

- A. True
- B. False

317. Safety precautions when using chlorine gas: In addition to protective clothing and goggles, chlorine gas should be used only in a well-ventilated area so that any leaking gas cannot concentrate.

- A. True
- B. False

318. Several symptoms of chlorine exposure: Burning of eyes, nose, and mouth, coughing, sneezing, choking, nausea and vomiting; headaches and dizziness; fatal pulmonary edema, pneumonia, and skin blisters.

- A. True B. False

319. When using chlorine gas: In addition to protective clothing and goggles, chlorine gas should be used only in a well-ventilated area so that any leaking gas cannot _____.

- A. Concentrate C. Combust
B. Conflagrate D. None of the above

320. HOCl and OCl⁻: The OCl⁻ is the hypochlorite ion and both of these species are known as free available chlorine, they are the two main chemical species formed by chlorine in water and they are known collectively as _____ and the _____.

- A. Hypochlorous acid, Cl₂ C. Combined Available Chlorine, Total
B. Hypochlorous acid, Hypochlorite ion D. None of the above

321. Which of the following terms when added to water, rapidly hydrolyzes, the chemical equations best describe this reaction is Cl₂ + H₂O → H⁺ + Cl⁻ + HOCl?

- A. Chlorine gas C. Combined Available Chlorine
B. Monochloramine D. None of the above

322. Which of the following is the most germicidal of the chlorine compounds with the possible exception of chlorine dioxide?

- A. Hydrochlorous acid C. Combined Available Chlorine
B. Hypochlorous acid D. None of the above

323. Monochloramine, Dichloramine, and trichloramine are known as _____. Cl₂ + NH₄.

- A. Hydrochlorous acid C. Combined Available Chlorine
B. Hypochlorous acid D. None of the above

Summary

Disinfection Byproducts

324. Which term represents when disinfectants used in water treatment plants react with bromide and/or natural organic matter present in the source water?

- A. Disinfection byproducts C. Occurring organic and inorganic matter in water
B. Naturally occurring bromide D. None of the above

325. Which term represents which regulations have been established have been identified in drinking water, including trihalomethanes, haloacetic acids, bromate, and chlorite?

- A. Chlorine dioxide C. Disinfection byproducts
B. HAA5 D. None of the above

Trihalomethanes (THM)

326. Which term represents are chloroform, bromodichloromethane, dibromochloromethane, and bromoform?

- A. Chloroform C. Trihalomethanes
B. HAA5 D. None of the above

Haloacetic Acids (HAA5)

327. Which term represents substances in drinking water react with naturally occurring organic and inorganic matter in water?

- A. Disinfection byproducts
- B. Microbial contaminants
- C. Occurring organic and inorganic matter in water
- D. None of the above

328. Which term represents monochloroacetic acid, dichloroacetic acid, trichloroacetic acid, monobromoacetic acid, and dibromoacetic acid?

- A. Chlorine dioxide
- B. HAA5
- C. Chlorite
- D. None of the above

329. Bromate is a chemical that is formed when _____ is used to disinfect drinking water reacts with naturally occurring bromide found in source water.

- A. Chlorine dioxide
- B. Ozone
- C. Chlorite
- D. None of the above

330. Which term represents a byproduct formed when chlorine dioxide is used to disinfect water?

- A. Chlorine dioxide
- B. HAA5
- C. Chlorite
- D. None of the above

Chloroform

331. Chloroform is typically the most prevalent _____ measured in chlorinated water, is probably the most thoroughly studied disinfection byproduct.

- A. HAA5
- B. THM
- C. Folic Acid
- D. None of the above

Sodium Chlorate

332. Sodium Chlorate can also be synthesized by passing _____ into a hot sodium hydroxide solution. It is then purified by crystallization.

- A. Chlorate
- B. Oxygen
- C. Chlorine gas
- D. None of the above

Chloramines

333. What are chemical compounds formed by combining a specific ratio of chlorine and ammonia in water?

- A. Disinfection byproducts
- B. Chloramines
- C. Trihalomethanes, haloacetic acids, bromate, and chlorite
- D. None of the above

334. Which term provides a durable residual, and are often used as a secondary disinfectant for long distribution lines and where free chlorine demand is high?

- A. Disinfection byproducts
- B. Chloramines
- C. Trihalomethanes, haloacetic acids, bromate, and chlorite
- D. None of the above

Chlorine Dioxide

335. Chlorine dioxide characteristics are quite different from _____. In solution, it is a dissolved gas, which makes it largely unaffected by pH but volatile and relatively easily stripped from solution.

- A. Chlorine
- B. Sodium hypochlorite
- C. Carbon dioxide
- D. None of the above

336. _____ is also a strong disinfectant and a selective oxidant. While chlorine dioxide does produce a residual, it is only rarely used for this purpose.
- A. Chlorine dioxide
 - B. Sodium hypochlorite
 - C. Carbon dioxide
 - D. None of the above

Factors in Chlorine Disinfection: Concentration and Contact Time

337. Which of the following terms is multiplied by minimum contact time (minutes)], offer water operators guidance in computing an effective combination of chlorine concentration and chlorine contact time required to achieve disinfection of water at a given temperature?

- A. CXT concept
- B. CXT values
- C. CXT formula
- D. None of the above

338. Which term demonstrates that if an operator chooses to decrease the chlorine concentration, the required contact time must be lengthened?

- A. CXT formula
- B. CXT values
- C. Pound per day
- D. None of the above

339. When free available chlorine residuals are desired, the characteristics of the water will determine how this will be accomplished. This may have to be considered:

If the water contains no ammonia or _____, any application of chlorine will yield a free residual once it has reacted with any bacteria, virus and other microorganisms present in the water.

- A. Other nitrogen compounds
- B. Chloramines
- C. Iron, manganese, organic matter
- D. None of the above

340. If the water contains _____, it results in the formation of a combined residual, which must be destroyed by applying an excess of chlorine.

- A. Ammonia
- B. Chloramines
- C. Iron, manganese, organic matter
- D. None of the above

Safety and Chlorination Equipment Section

Chlorination Equipment Requirements

341. Which of the following shall also be located inside the chlorine room?

- A. Gas vacuum line
- B. Vacuum regulators
- C. Mechanical gas proportioning equipment
- D. None of the above

342. Which of the following, which is the mechanical gas proportioning equipment, may or may not be located inside the chlorine room?

- A. Gas vacuum line
- B. Compound loop
- C. The chlorinator
- D. None of the above

343. _____ should be located to minimize the length of pressurized chlorine solution lines.

- A. Gas vacuum line
- B. Injectors
- C. Mechanical gas proportioning equipment
- D. None of the above

344. Which of the following shall be included in the gas vacuum line between the vacuum regulator(s) and the chlorinator(s) to ensure that pressurized chlorine gas does not enter the gas vacuum lines leaving the chlorine room?

- A. Gas vacuum line
- B. A gas pressure relief system
- C. Mechanical gas proportioning equipment
- D. None of the above

345. Which of the following shall have positive shutdown in the event of a break in the downstream vacuum lines?

- A. Gas vacuum line
- B. The vacuum regulating valve(s)
- C. A gas pressure relief system
- D. None of the above

346. Anti-siphon valves shall be incorporated in the _____ or in the discharge piping.

- A. Gas vacuum line
- B. A gas pressure relief system
- C. Pump heads
- D. None of the above

Capacity

347. Which of the following shall have the capacity to dose enough chlorine to overcome the demand and maintain the required concentration of the "free" or "combined" chlorine?

- A. The chlorinator
- B. Automatic proportional control
- C. Constant pre-established dosage
- D. None of the above

Methods of Control

348. Which of the following shall be automatic proportional controlled, automatic residual controlled, or compound loop controlled?

- A. A chlorine feed system
- B. Constant flow rate(s)
- C. Constant pre-established dosage
- D. None of the above

349. Which piece of chlorination equipment adjusts the chlorine feed rate automatically in accordance with the flow changes to provide a constant pre-established dosage for all rates of flow?

- A. Manual chlorine feed valve
- B. Constant flow rate(s)
- C. Automatic proportional control
- D. None of the above

350. Which piece of chlorination equipment is the feed rate of the chlorinator controlled by a flow proportional signal and a residual analyzer signal to maintain particular chlorine residual in the water?

- A. Manual chlorine feed systems
- B. Compound loop control system
- C. Mechanical gas proportioning equipment
- D. None of the above

Standby Provision

351. As a safeguard against _____, standby chlorination equipment having the capacity to replace the largest unit shall be provided.

- A. Uninterrupted chlorination
- B. Constant flow rate(s)
- C. Malfunction and/or shut-down
- D. None of the above

352. For uninterrupted chlorination, _____ shall be equipped with an automatic changeover system. In addition, spare parts shall be available for all chlorinators.

- A. Flow valves
- B. Flow regulators
- C. Gas chlorinators
- D. None of the above

353. Which of the following chlorine alarm equipment shall be installed at all water treatment plants using chlorine gas?

- A. Caustic soda solution reaction alarms
- B. Corrosion detection
- C. Automatic chlorine leak detection
- D. None of the above

354. Which of the following related chlorine alarm equipment should be connected to a remote audible and visual alarm system and checked on a regular basis to verify proper operation?

- A. Chlorine gas leakage alarm
- B. All chlorine cylinders
- C. Chlorine leak detection equipment
- D. None of the above

355. Leak detection equipment shall not automatically activate the chlorine room ventilation system in such a manner as to discharge chlorine gas.

- A. True B. False

356. During an emergency, if the chlorine room is occupied, the chlorine gas leakage shall be contained within the chlorine room itself in order to facilitate a proper method of clean-up.

- A. True B. False

357. Consideration should also be given to the provision of caustic soda solution reaction tanks for absorbing the contents of leaking one-ton cylinders where such cylinders are in use.

- A. True B. False

358. Chlorine leak detection equipment may not be required for very small chlorine rooms with an exterior door (e.g., floor area less than 3m²).

- A. True B. False

359. You can use a spray solution of sulfur dioxide or a rag soaked with sulfur dioxide to detect a small Cl₂ leak. If there is a leak, the sulfur dioxide will create a white colored smoke - sulfuric chloride.

- A. True B. False

Chlorine Room Design Requirements

360. Where gas chlorination is practiced, the gas cylinders and/or the ton containers up to the vacuum regulators shall be housed in a gas-tight, well illuminated, corrosion resistant and _____ ventilated enclosure.

- A. Mechanically C. Automatic chlorine leak detection
B. Securely positioned D. None of the above

361. _____ may or may not be located inside the chlorine room.

- A. The chlorinator C. Chlorine leak detection equipment
B. All chlorine cylinders D. None of the above

362. Which of the following shall have entirely separate exhaust ventilation systems capable of delivering one (1) complete air change per minute during periods of chlorine room occupancy only?

- A. Shut off C. Automatic chlorine leak detection
B. The chlorine room D. None of the above

363. _____ should be louvered near the ceiling, the air being of such temperature as to not adversely affect the chlorination equipment.

- A. Air inlets C. Automatic chlorine leak detection
B. Ventilation system D. None of the above

364. _____ should be outside the room at all entrance or viewing points and a clear wire-reinforced glass window shall be installed in such a manner as to allow the operator to inspect from the outside of the room.

- A. Separate switches for fans and lights C. Automatic chlorine leak detection
B. Chlorine room ventilation system D. None of the above

365. Chlorine rooms shall have _____, if a forced air system is used to heat the building.

- A. Corrosion filters C. Cooling system
B. Separate heating systems D. None of the above

366. _____ shall be protected to ensure that the chlorine maintains its gaseous state when entering the chlorinator.
- A. Cylinders or containers
 - B. Panic system
 - C. Equipment
 - D. None of the above

Storage of Chlorine Cylinders

367. Which chlorine safety related equipment term shall have provision for ventilation at thirty air changes per hour?
- A. Cylinders or containers access
 - B. Scrubber(s)
 - C. The chlorine gas storage room
 - D. None of the above
368. In very large facilities, entry into the chlorine rooms may be through a _____.
- A. Vestibule from inside
 - B. Chlorine gas storage room
 - C. Vestibule from outside
 - D. None of the above

Scrubbers

369. Facilities located within residential or densely populated areas, consideration shall be given to provide _____ for the chlorine room.
- A. Plan of attack
 - B. Scrubber(s)
 - C. Chlorine dozing plan
 - D. None of the above
370. Chlorine combines with a wide variety of materials. These side reactions complicate the use of chlorine for disinfecting purposes, their _____ must be satisfied before chlorine becomes available to accomplish disinfection.
- A. Combined residual
 - B. Free chlorine residual
 - C. Demand for chlorine
 - D. None of the above
371. Which term means the amount of chlorine required to produce a residual of 0.1 mg/l after a contact time of fifteen minutes as measured by Iodometric method of a sample at a temperature of twenty degrees in conformance with Standard methods?
- A. Combined residual
 - B. Free chlorine residual
 - C. Chlorine Demand
 - D. None of the above

Chlorine Health Hazard Section

372. Which term expresses low levels of chlorine results in eye, nose, and throat irritation, sneezing, Excessive salivation, general excitement, and restlessness?
- A. Rambling
 - B. Acute exposure
 - C. Chronic exposure
 - D. None of the above
373. Which term expresses low levels of chlorine gas can result in a dermatitis known as chloracne, tooth enamel corrosion, coughing, sore throat, hemoptysis and increased susceptibility to tuberculosis?
- A. Rambling
 - B. Acute exposure
 - C. Chronic exposure
 - D. None of the above

Inhalation

374. Which term expresses coughing, sneezing, shortness of breath, sensation of tightness in the chest, as well as severe restlessness or Anxiety, nausea, and vomiting?
- A. Inhalation
 - B. Acute exposure
 - C. Chronic exposure
 - D. None of the above

375. If you get chlorine in the eye, pour a gentle stream of _____ through the affected eye for at least 15 minutes. Contact the poison control center, emergency room or physician right away as further treatment will be necessary.

- A. Salt water
- B. Warm water
- C. Milk
- D. None of the above

376. If you get chlorine on the skin, run _____ over the affected area for 15 minutes.

- A. A gentle stream of water
- B. Warm water
- C. Cold water
- D. None of the above

Chronic

377. Repeated exposures to chlorine gas can result in a loss of ability to detect the odor of chlorine. Long-term exposures may cause damage to teeth and inflammation or?

- A. Chlorine gas toxicity
- B. Plasma exudation
- C. Ulceration of the nasal passages
- D. None of the above

Lab Analyst Section

378. Turbidity is measured to evaluate the performance of _____.

- A. Water treatment plant(s)
- B. An aesthetic point
- C. Colloidal to coarse dispersions
- D. None of the above

379. Turbidity is caused by wide variety of suspended matter that range in size from colloidal to coarse dispersions, depending upon the _____, and ranges from pure inorganic substances to those that are highly organic in nature.

- A. Water treatment plant(s)
- B. An aesthetic point
- C. Degree of turbulence
- D. None of the above

380. Turbid waters are undesirable from _____ of view in drinking water supplies.

- A. Water treatment plant(s)
- B. An aesthetic point
- C. Colloidal to coarse dispersions
- D. None of the above

Surface Water (SW) System Compliance

381. Sample the _____ at the clear well

- A. Individual filter effluent
- B. 95% of samples
- C. Combined filter turbidity
- D. None of the above

382. 0.34 NTU in _____, never to exceed 1.0 NTU spike

- A. Individual filter effluent
- B. 95% of samples
- C. Combined filter turbidity
- D. None of the above

383. Sample turbidity at each _____

- A. Individual filter effluent
- B. 95% of samples
- C. Combined filter turbidity
- D. None of the above

Disinfection Key

384. 99.9% or 3 log inactivation of _____

- A. Crypto
- B. Enteric viruses
- C. Giardia lamblia cysts
- D. None of the above

385. 99.99% or 4 log inactivation of _____
A. Crypto C. Giardia lamblia cysts
B. Enteric viruses D. None of the above

386. 99% or 2 log inactivation of _____
A. Crypto C. Giardia lamblia cysts
B. Enteric viruses D. None of the above

387. The chlorine residual leaving the plant must be = or _____ mg/L and measurable throughout the system.
A. > 0.2 C. < 0.2
B. ≤ 0.2 D. None of the above

Turbidity Key

388. Turbidity is normally measured in mg/L and its size is measured in multimeters.
A. True B. False

389. Turbidity can be particles in the water consisting of finely divided solids, larger than bacteria, visible by the naked eye; ranging in size from 10 to 150mm.
A. True B. False

Cloudy Water

390. In order to have gravity affect these particles, we must somehow make them larger, somehow have them come together (agglomerate); in other words, somehow make them “stick” together, thereby increasing their size and mass.
A. True B. False

Method 1623 - Cryptosporidium and Giardia Analysis

391. Special sterilization procedures are needed for equipment used in the collection of samples for?
A. Total Organisms C. Indicator bugs
B. Cryptosporidium and Giardia D. None of the above

392. Washing the equipment free of residual sodium hypochlorite solution with three rinses of filter-sterilized water; do not de-chlorinate the equipment using?
A. Sodium thiosulfate C. Sodium hypochlorite solution
B. Sulfuric acid D. None of the above

393. According to the text, composite the sample in a 10-L cubitainer that is pre-sterilized by the manufacturer. The cubitainer is sent in a cardboard box to laboratory for _____ analysis.
A. Cryptosporidium C. Cholera, polio, typhoid, hepatitis
B. Indicator organisms D. None of the above

Cryptosporidium and Giardia Analysis

394. For Cryptosporidium and Giardia analysis by Method 1623 (U.S. Environmental Protection Agency, 1999c), collect 10 L of streamwater for each protozoan pathogen using standard sampling techniques described in Myers and Sylvester (1997). Special sterilization procedures are needed for equipment used in the collection of samples for Cholera, polio, typhoid, hepatitis. Autoclaving is not effective in neutralizing the epitopes on the surfaces of the oocysts and cysts that will react with the antibodies used for detection.
A. True B. False

**Laboratory Analysis
Sample Procedures**

395. Samples need to be kept on ice and shipped to a central laboratory for analysis of coliphage, C. perfringens, Cryptosporidium, Giardia, and enteric viruses by the current analytical methods. The single-agar layer (SAL), direct plating method with induction of streptomycin and ampicillin is recommended for detection of somatic and F-specific coliphage in streamwater samples.

- A. True B. False

396. Fluorescently labeled antibodies and vital dye were used to make the final microscopic identification of?

- A. Enteric virus(es) C. Oocysts and cysts
B. Oocyst(s) D. None of the above

QA/QC Activities and Measures

397. QA/QC activities and measures to take to reduce contamination.

Use a sterilization indicator, such as autoclave tape, in preparing viral plaques and other equipment for collection of microbiological samples to determine whether adequate temperatures and pressures have been attained during autoclaving.

- A. True B. False

Hazard Communication Rule -Rationale

398. In order to guarantee _____ in the workplace, information about the identities and hazards of the chemicals must be available and understandable to workers.

- A. OSHA's HazCom rule C. Hazard information
B. Chemical safety D. None of the above

399. Chemical manufacturers and importers are required to calculate the _____ - they produce or import, and prepare labels and safety data sheets to convey the hazard information to their downstream customers;

- A. SDS/MSDS C. Specific criteria
B. Hazards of the chemicals D. None of the above

400. All employers with _____ in their workplaces must have labels and safety data sheets for their exposed workers, and train them to handle the chemicals appropriately.

- A. Hazardous chemicals C. Identities and hazards
B. Hazard information D. None of the above

When Finished with Your Assignment

REQUIRED DOCUMENTS

Please scan the **Registration Page, Answer Key, Survey and Driver's License** and email it to info@TLCH2O.com.

iPhone Scanning Instructions

If you are unable to scan, take a photo of these documents with your **iPhone** and send these photos to TLC, info@TLCH2O.com.

FAX

If you are unable to scan and email, please fax these to TLC, if you fax, call to confirm that we received your paperwork. **(928) 468-0675**